

Water Sampling – Como Park Elementary Final Report

Stohl Environmental  
3860 California Road Orchard Park, New York 14127  
Phone: 716-312-0070 Fax: 716-312-8092  
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski  
Director of Facilities  
Lancaster Central School District  
177 Central Avenue  
Lancaster, NY 14086

Regarding: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:  
Como Park Elementary – 1985 Como Park Boulevard, Lancaster, New York.

This report is prepared to assist the District in complying with the requirements of New York State regulations, Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the New York State "Action Level of 15 parts per billion (p.p.b)".

The Investigation and Sampling was performed on October 24, 2020. The Protocol for the Investigation followed the requirements of New York State regulations as well as United States Environmental Protection Agency Technical Guidance "3 T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 7 sources of potable water in Como Park Elementary has been identified as having lead concentration in water above the New York State Action Level of 15 parts per billion. To comply with New York State regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

"Signature of Eric Henderson Jr."  
Senior Project Manager

Investigation and Sampling of Sources of Potable Water for Lead Concentrations Prepared for: Lancaster Central School District Prepared by:

Stohl Environmental  
3860 California Road  
Orchard Park, New York 14127  
Phone (716) 312-0070 Fax (716) 312-8092  
www.stohlenvironmental.com

Conditions as of October 24, 2020

Summary Tabulation Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under New York State
- 1.4. Regulations Laboratory Analytical Reports by
- 1.5. Building Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

Como Park Elementary – 1985 Como Park Boulevard, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Transportation Department. Outlets are defined in New York State regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with New York State regulations, Subpart 67 -4: Lead Testing in School Drinking Water, and the Environmental Protection Agency guidance document, "3Ts for Reducing Lead in Drinking Water in Schools", Stohl Environmental's protocol can be summarized as follows:

First-draw samples of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the New York State Department of Health's Environmental Laboratory Approval Program (E L A P).

### 1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw and Confirmatory Samples:

The date of sample event on 10/24/2020 Como Park Elementary had a total of 68 samples collected. The First draw samples had 61 samples at or below action level of 15 parts per billion and 7 sample above action level of 15 parts per billion.

The date of sample event on 10/24/2020 Como Park Elementary had confirmatory samples at or below action level of 15 parts per billion and above action level of 15 parts per billion that are not applicable.

Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

#### Listings of Outlet Requiring Remediation

Locations of Outlets analyzed above New York State level of 15 parts per billion based upon analysis of first draw samples:

Sample Number 169.4-10	Room 114	Fixture	Bubbler	Laboratory Analysis parts per billion	181
Sample Number 169.4-20	Room 207	Fixture	Sink	Laboratory Analysis parts per billion	15.4
Sample Number 169.4-21	Room 208	Fixture	Sink	Laboratory Analysis parts per billion	47.0
Sample Number 169.4-30	Room 204	Fixture	Sink	Laboratory Analysis parts per billion	18.2
Sample Number 169.4-31	Room 211	Fixture	Sink	Laboratory Analysis parts per billion	18.1
Sample Number 169.4-57	Room 223	Fixture	Sink	Laboratory Analysis parts per billion	18.9
Sample Number 169.4-62	Girl's Lavatory Far Right	Fixture	Sink	Laboratory Analysis parts per billion	16.6

### 1.3 Response Actions Required Under New York State Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the New York State Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

### 1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, LLC  
7469 Whitepine Road  
Richmond, VA 23237  
Telephone: 800-347-4010

Lead in Drinking Water Analysis Report

Report Number: 20 - 10 - 0 6 1 2 5

Client: Stohl Environmental 3860 California Road Orchard Park, NY 14127

Received Date: 10/29/2020

Reported Date: 11/23/2020

Sampled By: P Nichols and C Schultz

Tech Certification Number:

Project Test Address: 2 0 2 0 L-169 .4; Como Park Elementary; 1985 Como Park Boulevard.; Lancaster, NY 14086

Client Number: 33-5 9 8 0

Fax Number: 716-312-8092

Laboratory Results

Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 1

Client Sample Identification Number 169.4-1

Collection date: 10/24/2020

Main Office Lavatory

Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 2

Client Sample Identification Number 169.4-2

Collection date: 10/24/2020

Main Office Hallway Lavatory

Micrograms per liter: 2.14

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 3

Client Sample Identification Number 169.4-3 A

Collection date: 10/24/2020

Main Office Hall Fountain Left

Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 4

Client Sample Identification Number 169.4-3 B

Collection date: 10/24/2020

Main Office Hall Fountain Left

Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 5

Client Sample Identification Number 169.4-4

Collection date: 10/24/2020

Main Office Hall Fountain Right

Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 6

Client Sample Identification Number 169.4-5

Collection date: 10/24/2020

Girl's Lavatory by Kitchen

Micrograms per liter: 5.08

Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 7  
Client Sample Identification Number 169.4-6  
Collection date: 10/24/2020  
Room 107  
Micrograms per liter: 6.61  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 8  
Client Sample Identification Number 169.4-7  
Collection date: 10/24/2020  
Room 108 Sink  
Micrograms per liter: 7.03  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 0 9  
Client Sample Identification Number 169.4-8  
Collection date: 10/24/2020  
Room 108 Bubbler  
Micrograms per liter: 1.34  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 10  
Client Sample Identification Number 169.4-9  
Collection date: 10/24/2020  
Room 114  
Micrograms per liter: 3.40  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 11  
Client Sample Identification Number 169.4-10  
Collection date: 10/24/2020  
Room 114  
Micrograms per liter: 181  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 12  
Client Sample Identification Number 169.4-11  
Collection date: 10/24/2020  
Room 114 Lavatory  
Micrograms per liter: 14.3  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 13  
Client Sample Identification Number 169.4-12  
Collection date: 10/24/2020  
Room 109  
Micrograms per liter: 5.24  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 14  
Client Sample Identification Number 169.4-13  
Collection date: 10/24/2020  
Room 113  
Micrograms per liter: 7.11

Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 15  
Client Sample Identification Number 169.4-14  
Collection date: 10/24/2020  
Room 113  
Micrograms per liter: 6.03  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 16  
Client Sample Identification Number 169.4-15  
Collection date: 10/24/2020  
Room 110 Art Room Left  
Micrograms per liter: 1.42  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 17  
Client Sample Identification Number 169.4-16  
Collection date: 10/24/2020  
Room 110 Art Room Right  
Micrograms per liter: 1.36  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 18  
Client Sample Identification Number 169.4-17  
Collection date: 10/24/2020  
Room 110 Art Room Lavatory  
Micrograms per liter: 5.29  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 19  
Client Sample Identification Number 169.4-18  
Collection date: 10/24/2020  
Room 112  
Micrograms per liter: 6.75  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 20  
Client Sample Identification Number 169.4-19  
Collection date: 10/24/2020  
Room 111  
Micrograms per liter: 2.90  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 21  
Client Sample Identification Number 169.4-20  
Collection date: 10/24/2020  
Room 207  
Micrograms per liter: 15.4  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 22  
Client Sample Identification Number 169.4-21  
Collection date: 10/24/2020  
Room 208  
Micrograms per liter: 47.0

Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 23  
Client Sample Identification Number 169.4-22 A  
Collection date: 10/24/2020  
Hallway Fountain Outside 205  
Micrograms per liter: less than 1.00  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 24  
Client Sample Identification Number 169.4-22 B  
Collection date: 10/24/2020  
Hallway Fountain Outside 205  
Micrograms per liter: less than 1.00  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 25  
Client Sample Identification Number 169.4-23  
Collection date: 10/24/2020  
Boy's Lavatory 206 Left  
Micrograms per liter: 9.32  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 26  
Client Sample Identification Number 169.4-25  
Collection date: 10/24/2020  
Room 209  
Micrograms per liter: 5.06  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 27  
Client Sample Identification Number 169.4-26  
Collection date: 10/24/2020  
Room 205  
Micrograms per liter: 10.4  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 28  
Client Sample Identification Number 169.4-28  
Collection date: 10/24/2020  
Girl's Ave 210  
Micrograms per liter: 3.88  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 29  
Client Sample Identification Number 169.4-30  
Collection date: 10/24/2020  
Room 204  
Micrograms per liter: 18.2  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 30  
Client Sample Identification Number 169.4-31  
Collection date: 10/24/2020  
Room 211  
Micrograms per liter: 18.1

Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 31  
Client Sample Identification Number 169.4-32  
Collection date: 10/24/2020  
Room 203  
Micrograms per liter: 14.4  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 32  
Client Sample Identification Number 169.4-33  
Collection date: 10/24/2020  
Room 202  
Micrograms per liter: 7.86  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 33  
Client Sample Identification Number 169.4-34  
Collection date: 10/24/2020  
Faculty Lavatory Second Floor  
Micrograms per liter: 1.44  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 34  
Client Sample Identification Number 169.4-35  
Collection date: 10/24/2020  
Room 212 Faculty Room  
Micrograms per liter: 9.83  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 35  
Client Sample Identification Number 169.4-36  
Collection date: 10/24/2020  
Kitchen Hand Wash  
Micrograms per liter: 1.95  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 36  
Client Sample Identification Number 169.4-37  
Collection date: 10/24/2020  
Kitchen Dish Sprayer  
Micrograms per liter: 2.49  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 37  
Client Sample Identification Number 169.4-38  
Collection date: 10/24/2020  
Kitchen 2 Bay Sink  
Micrograms per liter: 5.34  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 38  
Client Sample Identification Number 169.4-39  
Collection date: 10/24/2020  
Room 119  
Micrograms per liter: 3.16



Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 39  
Client Sample Identification Number 169.4-40  
Collection date: 10/24/2020  
Room 120  
Micrograms per liter: 3.95  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 40  
Client Sample Identification Number 169.4-42  
Collection date: 10/24/2020  
Girl's Locker Room  
Micrograms per liter: 2.57  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 41  
Client Sample Identification Number 169.4-43 A  
Collection date: 10/24/2020  
Hallway Outside 129  
Micrograms per liter: less than 1.00  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 42  
Client Sample Identification Number 169.4-43 B  
Collection date: 10/24/2020  
Hallway Outside 129  
Micrograms per liter: less than 1.00  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 43  
Client Sample Identification Number 169.4-44  
Collection date: 10/24/2020  
127 Library Media Center  
Micrograms per liter: 14.6  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 44  
Client Sample Identification Number 169.4-45  
Collection date: 10/24/2020  
Room 126 Main  
Micrograms per liter: 13.6  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 45  
Client Sample Identification Number 169.4-46  
Collection date: 10/24/2020  
Room 126 Lavatory  
Micrograms per liter: 10.5  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 46  
Client Sample Identification Number 169.4-47  
Collection date: 10/24/2020  
Room 125 Main  
Micrograms per liter: 8.74

Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 47  
Client Sample Identification Number 169.4-48  
Collection date: 10/24/2020  
Room 125 Lavatory  
Micrograms per liter: 4.42  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 48  
Client Sample Identification Number 169.4-49  
Collection date: 10/24/2020  
Room 106 Nurse Main  
Micrograms per liter: 13.8  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 49  
Client Sample Identification Number 169.4-50  
Collection date: 10/24/2020  
Room 106 Nurse Lavatory  
Micrograms per liter: 13.8  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 50  
Client Sample Identification Number 169.4-51  
Collection date: 10/24/2020  
Fountain Outside Nurse  
Micrograms per liter: 5.01  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 51  
Client Sample Identification Number 169.4-52  
Collection date: 10/24/2020  
Fountain Outside 227  
Micrograms per liter: 5.64  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 52  
Client Sample Identification Number 169.4-53  
Collection date: 10/24/2020  
Room 227  
Micrograms per liter: 1.47  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 53  
Client Sample Identification Number 169.4-54  
Collection date: 10/24/2020  
Room 226  
Micrograms per liter: less than 1.00  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 54  
Client Sample Identification Number 169.4-55  
Collection date: 10/24/2020  
Room 225  
Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 55  
Client Sample Identification Number 169.4-56  
Collection date: 10/24/2020  
Room 224  
Micrograms per liter: 1.75  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 56  
Client Sample Identification Number 169.4-57  
Collection date: 10/24/2020  
Room 223  
Micrograms per liter: 18.9  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 57  
Client Sample Identification Number 169.4-58  
Collection date: 10/24/2020  
Room 222 Faculty Main  
Micrograms per liter: 1.96  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 58  
Client Sample Identification Number 169.4-59  
Collection date: 10/24/2020  
Room 222 Faculty Lavatory Left  
Micrograms per liter: 2.69  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 59  
Client Sample Identification Number 169.4-60  
Collection date: 10/24/2020  
Room 222 Faculty Lavatory Right  
Micrograms per liter: 9.79  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 60  
Client Sample Identification Number 169.4-61 A  
Collection date: 10/24/2020  
Fountain Outside 222 Faculty  
Micrograms per liter: less than 1.00  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 61  
Client Sample Identification Number 169.4-61 B  
Collection date: 10/24/2020  
Fountain Outside 222 Faculty  
Micrograms per liter: less than 1.00  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 62  
Client Sample Identification Number 169.4-62  
Collection date: 10/24/2020  
Girl's Lavatory 220 Far Left  
Micrograms per liter: 16.6

Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 63  
Client Sample Identification Number 169.4-65  
Collection date: 10/24/2020  
Girl's Lavatory 220 Far Right  
Micrograms per liter: 4.67  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 64  
Client Sample Identification Number 169.4-66  
Collection date: 10/24/2020  
Boy's 218 Lavatory Left  
Micrograms per liter: 8.32  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 65  
Client Sample Identification Number 169.4-68  
Collection date: 10/24/2020  
Room 216 Main  
Micrograms per liter: 1.30  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 66  
Client Sample Identification Number 169.4-69  
Collection date: 10/24/2020  
Room 216 Lavatory  
Micrograms per liter: 3.31  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 67  
Client Sample Identification Number 169.4-70  
Collection date: 10/24/2020  
Room 215  
Micrograms per liter: 3.86  
Analysis Date: 11/19/2020  
Laboratory Sample Number: 20-10-0 6 1 2 5-0 68  
Client Sample Identification Number 169.4-71  
Collection date: 10/24/2020  
Room 214  
Micrograms per liter: 3.33  
Analysis Date: 11/19/2020

Method: SM 3 1 1 3 B – 2 0 1 0

Analyst: Jennalee Hertzler

Accreditation Number: New York 1 1 7 1 4

Reviewed and Authorized Signatory by Melissa Kanode; Quality Assurance Quality Control Clerk

Sample results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 part per billion.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 parts per billion. The results herein conform to National Environmental Laboratory Accreditation Conference standards, where

applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

## 1.5 Laboratory Certifications

New York State Department of Health Wadsworth Center

Certificate of Approval for Laboratory Service

issued in accordance with and pursuant to section 502 Public Health Law of New York state

Expires 12:01 AM April 01, 2021

Issued April 01, 2020

New York Laboratory Identification Number: 1 1 7 1 4

Ms. Julie Dickerson

Environmental Hazards Services, L.L.C.

7469 Whitepine Road

North Chesterfield, VA 23237

is hereby approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category Environmental Analyses Potable Water.

All approved analytes are listed below:

Metals 1

Copper, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Lead, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Serial Number: 6 1 5 1 4

Property of the New York State Department of Health. Certificates are valid only at the address shown; must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518)485-5570 to verify the laboratory's accreditation status.

## 1.6 Chains of Custody

Chain of Custody Document submitted to Environmental Hazards Services, L.L.C.

Stohl Job Number: 2 0 2 0 L -169 .4

Lancaster Central School District

Contact: Michael Bryniarski

Court Street Elementary

91 Court Street, Lancaster, New York 14086

Lead: Water by S M 19, 21-23 3 1 1 3 B (-04, -10)

Turnaround 20 days

Sample Number 169 .4-1	Main Office Lavatory	Outlet Type Sink	Time: 11:00
Sample Number 169 .4-2	Main Office Hallway Lavatory	Outlet Type Sink	Time 11:01
Sample Number 169 .4-3A	Main Office Hall Fountain Left	Outlet Type D F A	Time 11:02
Sample Number 169 .4-3B	Main Office Hall Fountain Left	Outlet Type D F B	Time 11:03
Sample Number 169 .4-4	Main Office Hall Fountain Right	Outlet Type D F A	Time 11:04
Sample Number 169 .4-5	Girl's Lavatory by Kitchen	Outlet Type Sink	Time 11:05
Sample Number 169 .4-6	Room 107	Outlet Type Sink	Time 11:06
Sample Number 169 .4-7	Room 108 Sink	Outlet Type Sink	Time 11:07
Sample Number 169 .4-8	Room 108 Bubbler	Outlet Type Bubbler	Time 11:08

Sample Number 169.4-9	Room 114	Outlet Type Sink	Time	11:09
Sample Number 169.4-10	Room 114	Outlet Type Bubbler	Time	11:10
Sample Number 169.4-11	Room 114 Lavatory	Outlet Type Sink	Time	11:11
Sample Number 169.4-12	Room 109	Outlet Type Sink	Time	11:12
Sample Number 169.4-13	Room 113	Outlet Type Sink	Time	11:13
Sample Number 169.4-14	Room 113	Outlet Type Bubbler	Time	11:14
Sample Number 169.4-15	Room 110 Art Room Left	Outlet Type Sink	Time	11:15
Sample Number 169.4-16	Room 110 Art Room Right	Outlet Type Sink	Time	11:16
Sample Number 169.4-17	Room 110 Art Room Lavatory	Outlet Type Sink	Time	11:17
Sample Number 169.4-18	Room 112	Outlet Type Sink	Time	11:18
Sample Number 169.4-19	Room 111	Outlet Type Sink	Time	11:19
Sample Number 169.4-20	Room 207	Outlet Type Sink	Time	11:20
Sample Number 169.4-21	Room 2018	Outlet Type Sink	Time	11:21
Sample Number 169.4-22A	Hallway Fountain Outside 205	Outlet Type Sink	Time	11:22
Sample Number 169.4-22B	Hallway Fountain Outside 205	Outlet Type Sink	Time	11:23
Sample Number 169.4-23	Boy's Lavatory 206 Left	Outlet Type Sink	Time	11:24
Sample Number 169.4-25	Room 209	Outlet Type Sink	Time	11:25
Sample Number 169.4-26	Room 205	Outlet Type Sink	Time	11:26
Sample Number 169.4-28	Girl's Ave 210	Outlet Type Sink	Time	11:27
Sample Number 169.4-30	Room 204	Outlet Type Sink	Time	11:28
Sample Number 169.4-31	Room 211	Outlet Type Sink	Time	11:29
Sample Number 169.4-32	Room 203	Outlet Type Sink	Time	11:30
Sample Number 169.4-33	Room 202	Outlet Type Sink	Time	11:31
Sample Number 169.4-34	Faculty Lavatory Second Floor	Outlet Type Sink	Time	11:32
Sample Number 169.4-35	Room 212 Faculty Room	Outlet Type Sink	Time	11:33
Sample Number 169.4-36	Kitchen Hand Wash	Outlet Type Sink	Time	11:34
Sample Number 169.4-37	Kitchen Dish Sprayer	Outlet Type Sink	Time	11:35
Sample Number 169.4-38	Kitchen 2 Bay Sink	Outlet Type Sink	Time	11:36
Sample Number 169.4-39	Room 119	Outlet Type Sink	Time	11:37
Sample Number 169.4-40	Room 120	Outlet Type Sink	Time	11:38
Sample Number 169.4-42	Girl's Locker Room	Outlet Type Sink	Time	11:39
Sample Number 169.4-43A	Hallway Outside 129	Outlet Type D F A	Time	11:40
Sample Number 169.4-43B	Hallway Outside 129	Outlet Type D F B	Time	11:41
Sample Number 169.4-44	127 Library Media Center	Outlet Type Sink	Time	11:42
Sample Number 169.4-45	Room 126 Main	Outlet Type Sink	Time	11:43
Sample Number 169.4-46	Room 126 Lavatory	Outlet Type Sink	Time	11:44
Sample Number 169.4-47	Room 125 Main	Outlet Type Sink	Time	11:45
Sample Number 169.4-48	Room 125 Lavatory	Outlet Type Sink	Time	11:46
Sample Number 169.4-49	Room 106 Nurse Main	Outlet Type Sink	Time	11:47
Sample Number 169.4-50	Room 106 Nurse Lavatory	Outlet Type Sink	Time	11:48
Sample Number 169.4-51	Fountain Outside Nurse	Outlet Type D F A	Time	11:49
Sample Number 169.4-52	Fountain Outside 227	Outlet Type D F A	Time	11:50
Sample Number 169.4-53	Room 227	Outlet Type Sink	Time	11:51
Sample Number 169.4-54	Room 226	Outlet Type Sink	Time	11:52
Sample Number 169.4-55	Room 225	Outlet Type Sink	Time	11:53
Sample Number 169.4-56	Room 224	Outlet Type Sink	Time	11:54
Sample Number 169.4-57	Room 223	Outlet Type Sink	Time	11:55
Sample Number 169.4-58	Room 222 Faculty Main	Outlet Type Sink	Time	11:56

Sample Number 169.4-59	Room 222 Faculty Lavatory Left	Outlet Type Sink	Time 11:57
Sample Number 169.4-60	Room 222 Faculty Lavatory Right	Outlet Type Sink	Time 11:58
Sample Number 169.4-61A	Fountain Outside 222 Faculty	Outlet Type D F A	Time 11:59
Sample Number 169.4-61B	Fountain Outside 222 Faculty	Outlet Type D F B	Time 12:00
Sample Number 169.4-62	Girl's Lavatory 220 Far Left	Outlet Type Sink	Time 12:01
Sample Number 169.4-65	Girl's Lavatory 220 Far Right	Outlet Type Sink	Time 12:02
Sample Number 169.4-66	Boy's 218 Lavatory Left	Outlet Type Sink	Time 12:03
Sample Number 169.4-68	Room 216 Main	Outlet Type Sink	Time 12:04
Sample Number 169.4-69	Room 216 Lavatory	Outlet Type Sink	Time 12:05
Sample Number 169.4-70	Room 215	Outlet Type Sink	Time 12:06
Sample Number 169.4-71	Room 214	Outlet Type Sink	Time 12:07

Please e-mail lab results to [labs@stohlenvironment.com](mailto:labs@stohlenvironment.com) If checked, also e-mail results to:  
[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: C Schultz, P Nichols Stohl Environmental 10/24/2020

Relinquished By: Eric Henderson Jr. 10/26/2020

Received (Name, Laboratory): signature 10/29/20 at 5:38pm

Sample Login (Name, Laboratory): T. Bloom 11/17/2020 at 4:51pm

Analysis (Name, Laboratory): J. Hertzler 11/20/2020 at 8:10am

Archived, Released: signature 11/23/2020 at 12pm