

Water Sampling – Court Street Elementary Final Report

Stohl Environmental
3860 California Road Orchard Park, New York 14127
Phone: 716-312-0070 Fax: 716-312-8092
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, NY 14086

Regarding: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:
Court Street Elementary – 91 Court Street, Lancaster, New York.

This report is prepared to assist the District in complying with the requirements of New York State regulations, Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the New York State "Action Level of 15 parts per billion (p.p.b)".

The Investigation and Sampling was performed on October 17, 2020. The Protocol for the Investigation followed the requirements of New York State regulations as well as United States Environmental Protection Agency Technical Guidance "3 T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 1 source of potable water in the Court Street Elementary has been identified as having lead concentration in water above the New York State Action Level of 15 parts per billion. To comply with New York State regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

"Signature of Eric Henderson Jr."
Senior Project Manager

Investigation and Sampling of Sources of Potable Water for Lead Concentrations Prepared for: Lancaster Central School District Prepared by:

Stohl Environmental
3860 California Road
Orchard Park, New York 14127
Phone (716) 312-0070 Fax (716) 312-8092
www.stohlenvironmental.com

Conditions as of October 30, 2020

Summary Tabulation Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under New York State
- 1.4. Regulations Laboratory Analytical Reports by
- 1.5. Building Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

Court Street Elementary – 91 Court Street, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Transportation Department. Outlets are defined in New York State regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with New York State regulations, Subpart 67 -4: Lead Testing in School Drinking Water, and the Environmental Protection Agency guidance document, "3Ts for Reducing Lead in Drinking Water in Schools", Stohl Environmental's protocol can be summarized as follows:

First-draw samples of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the New York State Department of Health's Environmental Laboratory Approval Program (E L A P).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw and Confirmatory Samples:

The date of sample event on 10/17/2020 Court Street Elementary had a total of 89 samples collected. The First draw samples had 88 samples at or below action level of 15 parts per billion and 1 sample above action level of 15 parts per billion.

The date of sample event on 10/17/2020 the Court Street Elementary had confirmatory samples at or below action level of 15 parts per billion and above action level of 15 parts per billion that are not applicable. Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listings of Outlet Requiring Remediation

Locations of Outlets analyzed above New York State level of 15 parts per billion based upon analysis of first draw samples:

Sample Number 169.5-10	Cafeteria Kitchen Hallway	Fixture	Bubbler	Laboratory Analysis parts per billion	19.8
------------------------	---------------------------	---------	---------	---------------------------------------	------

1.3 Response Actions Required Under New York State Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the New York State Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, LLC
7469 Whitepine Road
Richmond, VA 23237
Telephone: 800-347-4010

Lead in Drinking Water Analysis Report

Report Number: 20 - 10 - 0 4 9 0 4

Client: Stohl Environmental 3860 California Road Orchard Park, NY 14127

Received Date: 10/22/2020

Reported Date: 11/11/2020

Sampled By: Christine Schultz

Tech Certification Number:

Project Test Address: 2 0 2 0 L-169 .5; Court Street Elementary; 91 Court Street.; Lancaster, NY 14086
Client Number: 33 - 5 9 8 0
Fax Number: 716-312-8092

Laboratory Results

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 1

Client Sample Identification Number 169.5-1

Collection date: 10/17/2020

Gym Office Lavatory

Micrograms per liter: 12.0

Analysis Date: 11/9/2020

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 2

Client Sample Identification Number 169.5-2

Collection date: 10/17/2020

Gym Classroom

Micrograms per liter: 9.62

Analysis Date: 11/9/2020

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 3

Client Sample Identification Number 169.5-3

Collection date: 10/17/2020

Kitchen Sprayer

Micrograms per liter: 4.53

Analysis Date: 11/9/2020

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 4

Client Sample Identification Number 169.5-4

Collection date: 10/17/2020

Kitchen Single Bay Center

Micrograms per liter: 4.59

Analysis Date: 11/9/2020

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 5

Client Sample Identification Number 169.5-5

Collection date: 10/17/2020

Kitchen Lavatory

Micrograms per liter: 5.67

Analysis Date: 11/9/2020

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 6

Client Sample Identification Number 169.5-6

Collection date: 10/17/2020

Kitchen Handwash

Micrograms per liter: 2.40

Analysis Date: 11/9/2020

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 7

Client Sample Identification Number 169.5-7

Collection date: 10/17/2020

Kitchen 3 Bay Left

Micrograms per liter: 4.29

Analysis Date: 11/9/2020

Laboratory Sample Number: 20-10-0 4 9 0 4 - 0 0 8

Client Sample Identification Number 169.5-8
Collection date: 10/17/2020
Kitchen 3 Bay Right
Micrograms per liter: 4.10
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 0 9
Client Sample Identification Number 169.5-9
Collection date: 10/17/2020
Cafeteria
Micrograms per liter: 7.04
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 0
Client Sample Identification Number 169.5-10
Collection date: 10/17/2020
Cafeteria Kitchen Hallway
Micrograms per liter: 19.8
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 1
Client Sample Identification Number 169.5-11
Collection date: 10/17/2020
Gym Passage Left Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 2
Client Sample Identification Number 169.5-12
Collection date: 10/17/2020
Gym Passage
Micrograms per liter: 1.92
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 3
Client Sample Identification Number 169.5-13
Collection date: 10/17/2020
Gym Passage
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 4
Client Sample Identification Number 169.5-14
Collection date: 10/17/2020
Gym Passage Right Lavatory
Micrograms per liter: 10.2
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 5
Client Sample Identification Number 169.5-15
Collection date: 10/17/2020
Room 179
Micrograms per liter: 4.05
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 6

Client Sample Identification Number 169.5-16
Collection date: 10/17/2020
Faculty Room
Micrograms per liter: 2.63
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 7
Client Sample Identification Number 169.5-17
Collection date: 10/17/2020
Room 103
Micrograms per liter: 1.49
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 8
Client Sample Identification Number 169.5-18
Collection date: 10/17/2020
Boys Lavatory Left
Micrograms per liter: 4.45
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 1 9
Client Sample Identification Number 169.5-19
Collection date: 10/17/2020
Boys Lavatory Center
Micrograms per liter: 5.63
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 0
Client Sample Identification Number 169.5-20
Collection date: 10/17/2020
Boys Lavatory Right
Micrograms per liter: 4.84
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 1
Client Sample Identification Number 169.5-21
Collection date: 10/17/2020
Fountain between Lavatories
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 2
Client Sample Identification Number 169.5-22
Collection date: 10/17/2020
Girls Lavatory Left
Micrograms per liter: 5.74
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 3
Client Sample Identification Number 169.5-23
Collection date: 10/17/2020
Girls Lavatory Center
Micrograms per liter: 8.31
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 4

Client Sample Identification Number 169.5-24
Collection date: 10/17/2020
Girls lavatory Right
Micrograms per liter: 4.25
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 5
Client Sample Identification Number 169.5-25
Collection date: 10/17/2020
Room 111
Micrograms per liter: 3.20
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 6
Client Sample Identification Number 169.5-26
Collection date: 10/17/2020
Faculty Lavatory 1
Micrograms per liter: 4.26
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 7
Client Sample Identification Number 169.5-27
Collection date: 10/17/2020
Faculty Lavatory 2
Micrograms per liter: 3.48
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 8
Client Sample Identification Number 169.5-28
Collection date: 10/17/2020
Room 105
Micrograms per liter: 8.78
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 2 9
Client Sample Identification Number 169.5-29
Collection date: 10/17/2020
Room 110
Micrograms per liter: 4.08
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 0
Client Sample Identification Number 169.5-30
Collection date: 10/17/2020
Room 106
Micrograms per liter: 4.51
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 1
Client Sample Identification Number 169.5-31
Collection date: 10/17/2020
Room 109
Micrograms per liter: 6.13
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 2

Client Sample Identification Number 169.5-32
Collection date: 10/17/2020
Room 107
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 3
Client Sample Identification Number 169.5-33
Collection date: 10/17/2020
Room 108
Micrograms per liter: 6.44
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 4
Client Sample Identification Number 169.5-34
Collection date: 10/17/2020
Media Center 102
Micrograms per liter: 3.35
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 5
Client Sample Identification Number 169.5-35A
Collection date: 10/17/2020
Cafeteria Hallway Toward Principal
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 6
Client Sample Identification Number 169.5-35B
Collection date: 10/17/2020
Cafeteria Hallway Toward Principal
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 7
Client Sample Identification Number 169.5-36
Collection date: 10/17/2020
Principal Lavatory
Micrograms per liter: 8.89
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 8
Client Sample Identification Number 169.5-37
Collection date: 10/17/2020
Men's Lavatory Principal Left
Micrograms per liter: 3.92
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 3 9
Client Sample Identification Number 169.5-38
Collection date: 10/17/2020
Men's Lavatory Principal Right
Micrograms per liter: 3.75
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 0

Client Sample Identification Number 169.5-39
Collection date: 10/17/2020
Nurse Office Lavatory
Micrograms per liter: 5.44
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 1
Client Sample Identification Number 169.5-40
Collection date: 10/17/2020
Nurse Office Main
Micrograms per liter: 7.99
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 2
Client Sample Identification Number 169.5-41
Collection date: 10/17/2020
Girl's Lavatory by Office Left
Micrograms per liter: 6.68
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 3
Client Sample Identification Number 169.5-42
Collection date: 10/17/2020
Girl's Lavatory by Office Right
Micrograms per liter: 6.89
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 4
Client Sample Identification Number 169.5-43
Collection date: 10/17/2020
Single Lavatory End of North Wing
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 5
Client Sample Identification Number 169.5-44A
Collection date: 10/17/2020
Fountain End of North Wing
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 6
Client Sample Identification Number 169.5-44B
Collection date: 10/17/2020
Fountain End of North Wing
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 7
Client Sample Identification Number 169.5-45
Collection date: 10/17/2020
Room 132 Lavatory
Micrograms per liter: 4.85
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 8

Client Sample Identification Number 169.5-46
Collection date: 10/17/2020
Room 132
Micrograms per liter: 7.10
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 4 9
Client Sample Identification Number 169.5-47
Collection date: 10/17/2020
Room 132
Micrograms per liter: 3.96
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 0
Client Sample Identification Number 169.5-48
Collection date: 10/17/2020
Room 131 Lavatory
Micrograms per liter: 3.52
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 1
Client Sample Identification Number 169.5-49
Collection date: 10/17/2020
Room 131
Micrograms per liter: 6.21
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 2
Client Sample Identification Number 169.5-50
Collection date: 10/17/2020
Room 131
Micrograms per liter: 1.26
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 3
Client Sample Identification Number 169.5-51
Collection date: 10/17/2020
Room 124 Lavatory
Micrograms per liter: 2.99
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 4
Client Sample Identification Number 169.5-52
Collection date: 10/17/2020
Room 124
Micrograms per liter: 6.38
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 5
Client Sample Identification Number 169.5-53
Collection date: 10/17/2020
Room 124
Micrograms per liter: 6.33
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 6

Client Sample Identification Number 169.5-54
Collection date: 10/17/2020
Room 130 Lavatory
Micrograms per liter: 2.11
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 7
Client Sample Identification Number 169.5-55
Collection date: 10/17/2020
Room 130
Micrograms per liter: 3.74
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 8
Client Sample Identification Number 169.5-56
Collection date: 10/17/2020
Room 130
Micrograms per liter: 4.64
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 5 9
Client Sample Identification Number 169.5-57
Collection date: 10/17/2020
Room 125 Lavatory
Micrograms per liter: 3.88
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 0
Client Sample Identification Number 169.5-58
Collection date: 10/17/2020
Room 125
Micrograms per liter: 4.33
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 1
Client Sample Identification Number 169.5-59
Collection date: 10/17/2020
Room 125
Micrograms per liter: 1.27
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 2
Client Sample Identification Number 169.5-60
Collection date: 10/17/2020
Room 129 Lavatory
Micrograms per liter: 3.44
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 3
Client Sample Identification Number 169.5-61
Collection date: 10/17/2020
Room 129
Micrograms per liter: 4.32
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 4

Client Sample Identification Number 169.5-62
Collection date: 10/17/2020
Room 129
Micrograms per liter: 8.88
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 5
Client Sample Identification Number 169.5-63
Collection date: 10/17/2020
Room 126 Lavatory
Micrograms per liter: 3.64
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 6
Client Sample Identification Number 169.5-64
Collection date: 10/17/2020
Room 126
Micrograms per liter: 5.32
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 7
Client Sample Identification Number 169.5-65
Collection date: 10/17/2020
Room 126
Micrograms per liter: 6.94
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 8
Client Sample Identification Number 169.5-66
Collection date: 10/17/2020
Room 128 Lavatory
Micrograms per liter: 2.71
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 6 9
Client Sample Identification Number 169.5-67
Collection date: 10/17/2020
Room 128
Micrograms per liter: 4.06
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 0
Client Sample Identification Number 169.5-68
Collection date: 10/17/2020
Room 128
Micrograms per liter: 10.3
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 1
Client Sample Identification Number 169.5-69
Collection date: 10/17/2020
Room 127 Lavatory
Micrograms per liter: 2.71
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 2

Client Sample Identification Number 169.5-70
Collection date: 10/17/2020
Room 127
Micrograms per liter: 10.5
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 3
Client Sample Identification Number 169.5-71
Collection date: 10/17/2020
Room 127
Micrograms per liter: 3.93
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 4
Client Sample Identification Number 169.5-72
Collection date: 10/17/2020
Room 118 Lavatory
Micrograms per liter: 2.36
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 5
Client Sample Identification Number 169.5-73
Collection date: 10/17/2020
Room 118
Micrograms per liter: 2.37
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 6
Client Sample Identification Number 169.5-74
Collection date: 10/17/2020
Room 118
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 7
Client Sample Identification Number 169.5-75
Collection date: 10/17/2020
Room 118B
Micrograms per liter: 13.4
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 8
Client Sample Identification Number 169.5-76
Collection date: 10/17/2020
Room 119 Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 7 9
Client Sample Identification Number 169.5-77
Collection date: 10/17/2020
Room 119
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 0

Client Sample Identification Number 169.5-78
Collection date: 10/17/2020
Room 119
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 1
Client Sample Identification Number 169.5-79
Collection date: 10/17/2020
Room 120 Lavatory
Micrograms per liter: 2.98
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 2
Client Sample Identification Number 169.5-80
Collection date: 10/17/2020
Room 120
Micrograms per liter: 6.30
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 3
Client Sample Identification Number 169.5-81
Collection date: 10/17/2020
Room 120
Micrograms per liter: 3.18
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 4
Client Sample Identification Number 169.5-82
Collection date: 10/17/2020
Room 121 Lavatory
Micrograms per liter: 1.60
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 5
Client Sample Identification Number 169.5-83
Collection date: 10/17/2020
Room 121 Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 6
Client Sample Identification Number 169.5-84
Collection date: 10/17/2020
Room 121 Lavatory
Micrograms per liter: 3.96
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 7
Client Sample Identification Number 169.5-85
Collection date: 10/17/2020
Room 122
Micrograms per liter: 4.40
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 8

Client Sample Identification Number 169.5-86
Collection date: 10/17/2020
Room 122
Micrograms per liter: 1.23
Analysis Date: 11/9/2020
Laboratory Sample Number: 20-10-0 4 9 04 - 0 8 9
Client Sample Identification Number 169.5-87
Collection date: 10/17/2020
Basement Shop
Micrograms per liter: 2.80
Analysis Date: 11/9/2020

Method: SM 3 1 1 3 B – 2 0 1 0
Analyst: Jennalee Hertzler
Accreditation Number: New York 1 1 7 1 4
Reviewed and Authorized Signatory by Melissa Kanode; Quality Assurance Quality Control Clerk

Sample results denoted with a "less than" (<) sign contain less than the reporting limit which is 1 part per billion.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 parts per billion. The results herein conform to National Environmental Laboratory Accreditation Conference standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

1.5 Laboratory Certifications

New York State Department of Health Wadsworth Center
Certificate of Approval for Laboratory Service
issued in accordance with and pursuant to section 502 Public Health Law of New York state
Expires 12:01 AM April 01, 2021
Issued April 01, 2020
New York Laboratory Identification Number: 1 1 7 1 4

Ms. Julie Dickerson
Environmental Hazards Services, L.L.C.
7469 Whitepine Road
North Chesterfield, VA 23237

is hereby approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category Environmental Analyses Potable Water.

All approved analytes are listed below:

Metals 1

Copper, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Lead, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Serial Number: 6 1 5 1 4

Property of the New York State Department of Health. Certificates are valid only at the address shown; must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518)485-5570 to verify the laboratory's accreditation status.

1.6 Chains of Custody

Chain of Custody Document submitted to Environmental Hazards Services, L.L.C.

Stohl Job Number: 2 0 2 0 L -169 .5

Lancaster Central School District

Contact: Michael Bryniarski

Court Street Elementary

91 Court Street, Lancaster, New York 14086

Lead: Water by S M 19, 21-23 3 1 1 3 B (-04, -10)

Turnaround 20 days

Sample Number 169 .5-1	Gym Office Lavatory	Outlet Type Sink	Time: 14:30
Sample Number 169 .5-2	Gym Classroom	Outlet Type Sink	Time 14:31
Sample Number 169 .5-3	Kitchen Sprayer	Outlet Type Sink	Time 14:32
Sample Number 169 .5-4	Kitchen Single Bay Center	Outlet Type Sink	Time 14:33
Sample Number 169 .5-5	Kitchen Lavatory	Outlet Type Sink	Time 14:34
Sample Number 169 .5-6	Kitchen Handwash	Outlet Type Sink	Time 14:35
Sample Number 169 .5-7	Kitchen 3 Bay Left	Outlet Type Sink	Time 14:36
Sample Number 169 .5-8	Kitchen 3 Bay Right	Outlet Type Sink	Time 14:37
Sample Number 169 .5-9	Cafeteria	Outlet Type D F	Time 14:38

Sample Number 169.5-10	Cafeteria Kitchen Hallway	Outlet Type Bubbler	Time 14:39
Sample Number 169.5-11	Gym Passage Left Lavatory	Outlet Type Sink	Time 14:40
Sample Number 169.5-12	Gym Passage	Outlet Type Sink	Time 14:41
Sample Number 169.5-13	Gym Passage	Outlet Type D F	Time 14:42
Sample Number 169.5-14	Gym Passage Right Lavatory	Outlet Type Sink	Time 14:43
Sample Number 169.5-15	Room 179	Outlet Type Sink	Time 14:44
Sample Number 169.5-16	Faculty Room	Outlet Type Sink	Time 14:45
Sample Number 169.5-17	Room 103	Outlet Type Sink	Time 14:46
Sample Number 169.5-18	Boys Lavatory Left	Outlet Type Sink	Time 14:47
Sample Number 169.5-19	Boys Lavatory Center	Outlet Type Sink	Time 14:48
Sample Number 169.5-20	Boys Lavatory Right	Outlet Type Sink	Time 14:49
Sample Number 169.5-21	Fountain Between Lavatories	Outlet Type D F	Time 14:50
Sample Number 169.5-22	Girl's Lavatory Left	Outlet Type Sink	Time 14:51
Sample Number 169.5-23	Girl's Lavatory Center	Outlet Type Sink	Time 14:52
Sample Number 169.5-24	Girl's Lavatory Right	Outlet Type Sink	Time 14:53
Sample Number 169.5-25	Room 111	Outlet Type Sink	Time 14:54
Sample Number 169.5-26	Faculty Lavatory 1	Outlet Type Sink	Time 14:55
Sample Number 169.5-27	Faculty Lavatory 2	Outlet Type Sink	Time 14:56
Sample Number 169.5-28	Room 105	Outlet Type Sink	Time 14:57
Sample Number 169.5-29	Room 110	Outlet Type Sink	Time 14:58
Sample Number 169.5-30	Room 106	Outlet Type Sink	Time 14:59
Sample Number 169.5-31	Room 109	Outlet Type Sink	Time 15:00
Sample Number 169.5-32	Room 107	Outlet Type Sink	Time 15:01
Sample Number 169.5-33	Room 108	Outlet Type Sink	Time 15:02
Sample Number 169.5-34	Media Center 102	Outlet Type Sink	Time 15:03
Sample Number 169.5-35A	Cafeteria Hallway towards Principal	Outlet Type D F	Time 15:04
Sample Number 169.5-35B	Cafeteria Hallway towards Principal	Outlet Type D F B	Time 15:05
Sample Number 169.5-36	Principal Lavatory	Outlet Type Sink	Time 15:06
Sample Number 169.5-37	Men's Lavatory by Principal Left	Outlet Type Sink	Time 15:07
Sample Number 169.5-38	Men's Lavatory by Principal Right	Outlet Type Sink	Time 15:08
Sample Number 169.5-39	Nurse Office Lavatory	Outlet Type Sink	Time 15:09
Sample Number 169.5-40	Nurse Office Main	Outlet Type Sink	Time 15:10
Sample Number 169.5-41	Girl's Lavatory by Office Left	Outlet Type Sink	Time 15:11
Sample Number 169.5-42	Girl's Lavatory by Office Right	Outlet Type Sink	Time 15:12
Sample Number 169.5-43	Single Lavatory End of North Wing	Outlet Type Sink	Time 15:13
Sample Number 169.5-44A	Fountain End of North Wing	Outlet Type D F	Time 15:14
Sample Number 169.5-44B	Fountain End of North Wing	Outlet Type D F B	Time 15:15
Sample Number 169.5-45	Room 132 Lavatory	Outlet Type Sink	Time 15:16
Sample Number 169.5-46	Room 132	Outlet Type Bubbler	Time 15:17
Sample Number 169.5-47	Room 132	Outlet Type Sink	Time 15:18
Sample Number 169.5-48	Room 131 Lavatory	Outlet Type Sink	Time 15:19
Sample Number 169.5-49	Room 131	Outlet Type Bubbler	Time 15:20
Sample Number 169.5-50	Room 131	Outlet Type Sink	Time 15:21
Sample Number 169.5-51	Room 124 Lavatory	Outlet Type Sink	Time 15:22
Sample Number 169.5-52	Room 124	Outlet Type Bubbler	Time 15:23
Sample Number 169.5-53	Room 124	Outlet Type Sink	Time 15:24
Sample Number 169.5-54	Room 130 Lavatory	Outlet Type Sink	Time 15:25
Sample Number 169.5-55	Room 130	Outlet Type Bubbler	Time 15:26

Sample Number 169.5-56	Room 130	Outlet Type Sink	Time	15:27
Sample Number 169.5-57	Room 125 Lavatory	Outlet Type Sink	Time	15:28
Sample Number 169.5-58	Room 125	Outlet Type Bubbler	Time	15:29
Sample Number 169.5-59	Room 125	Outlet Type Sink	Time	15:30
Sample Number 169.5-60	Room 129 Lavatory	Outlet Type Sink	Time	15:31
Sample Number 169.5-61	Room 129	Outlet Type Bubbler	Time	15:32
Sample Number 169.5-62	Room 129	Outlet Type Sink	Time	15:33
Sample Number 169.5-63	Room 126 Lavatory	Outlet Type Sink	Time	15:34
Sample Number 169.5-64	Room 126	Outlet Type Bubbler	Time	15:35
Sample Number 169.5-65	Room 126	Outlet Type Sink	Time	15:36
Sample Number 169.5-66	Room 128 Lavatory	Outlet Type Sink	Time	15:37
Sample Number 169.5-67	Room 128	Outlet Type Bubbler	Time	15:38
Sample Number 169.5-68	Room 128	Outlet Type Sink	Time	15:39
Sample Number 169.5-69	Room 127 Lavatory	Outlet Type Sink	Time	15:40
Sample Number 169.5-70	Room 127	Outlet Type Bubbler	Time	15:41
Sample Number 169.5-71	Room 127	Outlet Type Sink	Time	15:42
Sample Number 169.5-72	Room 118 Lavatory	Outlet Type Sink	Time	15:43
Sample Number 169.5-73	Room 118	Outlet Type Bubbler	Time	15:44
Sample Number 169.5-74	Room 118	Outlet Type Sink	Time	15:45
Sample Number 169.5-75	Room 118B	Outlet Type Sink	Time	15:46
Sample Number 169.5-76	Room 119 Lavatory	Outlet Type Sink	Time	15:47
Sample Number 169.5-77	Room 119	Outlet Type Bubbler	Time	15:48
Sample Number 169.5-78	Room 119	Outlet Type Sink	Time	15:49
Sample Number 169.5-79	Room 120 Lavatory	Outlet Type Sink	Time	15:50
Sample Number 169.5-80	Room 120	Outlet Type Bubbler	Time	15:51
Sample Number 169.5-81	Room 120	Outlet Type Sink	Time	15:52
Sample Number 169.5-82	Room 121 Lavatory	Outlet Type Sink	Time	15:53
Sample Number 169.5-83	Room 121 Lavatory	Outlet Type Bubbler	Time	15:54
Sample Number 169.5-84	Room 122 Lavatory	Outlet Type Sink	Time	15:55
Sample Number 169.5-85	Room 122	Outlet Type Bubbler	Time	15:56
Sample Number 169.5-86	Room 122	Outlet Type Sink	Time	15:57
Sample Number 169.5-87	Basement Shop	Outlet Type Sink	Time	15:58

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to:

Ehenderson@StohlEnv.com

Sampled By: Christine Schultz Stohl Environmental 10/17/2020

Relinquished By: Eric Henderson Jr. 10/19/2020

Received (Name, Laboratory): K T Harris 10/22/20 at 1:27pm

Sample Login (Name, Laboratory): K Harris 11/4/2020 at 12:36pm

Analysis (Name, Laboratory): J. Hertzler 11/10/2020 at 9:00am

Archived, Released: signature 11/11/2020 at 12pm