

Water Sampling – John A. Sciole Elementary Final Report

Stohl Environmental  
3860 California Road Orchard Park, New York 14127  
Phone: 716-312-0070 Fax: 716-312-8092  
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski  
Director of Facilities  
Lancaster Central School District  
177 Central Avenue  
Lancaster, NY 14086

Regarding: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:  
John A. Sciole Elementary – 86 Alys Drive, Depew, New York.

This report is prepared to assist the District in complying with the requirements of New York State regulations, Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the New York State "Action Level of 15 parts per billion (p.p.b)".

The Investigation and Sampling was performed on October 24, 2020. The Protocol for the Investigation followed the requirements of New York State regulations as well as United States Environmental Protection Agency Technical Guidance "3 T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 3 sources of potable water in Central Avenue School have been identified as having lead concentration in water above the New York State Action Level of 15 parts per billion. To comply with New York State regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

"Signature of Eric Henderson Jr."  
Senior Project Manager

Investigation and Sampling of Sources of Potable Water for Lead Concentrations Prepared for: Lancaster Central School District Prepared by:

Stohl Environmental  
3860 California Road  
Orchard Park, New York 14127  
Phone (716) 312-0070 Fax (716) 312-8092  
www.stohlenvironmental.com

Conditions as of October 24, 2020

Summary Tabulation Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under New York State
- 1.4. Regulations Laboratory Analytical Reports by
- 1.5. Building Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

John A. Sciole – 86 Alys Drive, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Transportation Department. Outlets are defined in New York State regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with New York State regulations, Subpart 67 -4: Lead Testing in School Drinking Water, and the Environmental Protection Agency guidance document, "3Ts for Reducing Lead in Drinking Water in Schools", Stohl Environmental's protocol can be summarized as follows:

First-draw samples of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the New York State Department of Health's Environmental Laboratory Approval Program (E L A P).

## 1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw and Confirmatory Samples:

The date of sample event on 10/24/2020 John A. Sciole Elementary had a total of 68 samples collected.

The First draw samples had 65 samples at or below action level of 15 parts per billion and 3 samples above action level of 15 parts per billion.

The date of sample event on 10/24/2020 John A. Sciole Elementary had confirmatory samples at or below action level of 15 parts per billion and above action level of 15 parts per billion that are not applicable.

Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listings of Outlet Requiring Remediation

Locations of Outlets analyzed above New York State level of 15 parts per billion based upon analysis of first draw samples:

Sample Number 169.7-2	Room 1	Fixture	Sink	Laboratory Analysis parts per billion	23.0
Sample Number 169.7-25	Faculty Lavatory Left	Fixture	Sink	Laboratory Analysis parts per billion	not analyzed
Sample Number 169.7-32	Room 18	Fixture	Sink	Laboratory Analysis parts per billion	not analyzed
Sample Number 169.7-57	Outdoor Restroom	Fixture	Sink	Laboratory Analysis parts per billion	17.2
Sample Number 169.7-61	Kitchen Pan Fill	Fixture	Sink	Laboratory Analysis parts per billion	25.7

Sample Number 169-7-25 and Sample Number 169-7-32 were not analyzed. The laboratory received the sample empty and was not able to be analyzed. Location should be resampled and analyzed at a later date.

## 1.3 Response Actions Required Under New York State Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the New York State Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

## 1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, LLC  
7469 Whitepine Road  
Richmond, VA 23237  
Telephone: 800-347-4010

Lead in Drinking Water Analysis Report

Report Number: 20 - 10 - 0 6 1 3 0

Client: Stohl Environmental 3860 California Road Orchard Park, NY 14127

Received Date: 10/29/2020

Reported Date: 11/24/2020

Sampled By: P Nichols and C Schultz

Tech Certification Number:

Project Test Address: 2 0 2 0 L-169 .7; John A. Sciole Elementary; 86 Alys Drive.; Depew, NY 14043

Client Number: 33-5 9 8 0

Fax Number: 716-312-8092

Laboratory Results

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 1

Client Sample Identification Number 169.7-1

Collection date: 10/24/2020

Room 2

Micrograms per liter: less than 1.00

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 2

Client Sample Identification Number 169.7-2

Collection date: 10/24/2020

Room 1

Micrograms per liter: 23.0

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 3

Client Sample Identification Number 169.7-3

Collection date: 10/24/2020

Room 4

Micrograms per liter: 4.27

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 4

Client Sample Identification Number 169.7-4

Collection date: 10/24/2020

Room 3

Micrograms per liter: 9.10

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 5

Client Sample Identification Number 169.7-5

Collection date: 10/24/2020

Room 6

Micrograms per liter: 8.81

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 6

Client Sample Identification Number 169.7-6

Collection date: 10/24/2020

Room 5

Micrograms per liter: 3.99

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 7

Client Sample Identification Number 169.7-7

Collection date: 10/24/2020

Room 8

Micrograms per liter: 4.45

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 8

Client Sample Identification Number 169.7-8

Collection date: 10/24/2020

Room 7

Micrograms per liter: 6.16

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 0 9

Client Sample Identification Number 169.7-9

Collection date: 10/24/2020

Room 10

Micrograms per liter: 5.75

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 10

Client Sample Identification Number 169.7-10

Collection date: 10/24/2020

Room 9

Micrograms per liter: 7.43

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 11

Client Sample Identification Number 169.7-11

Collection date: 10/24/2020

Room 12

Micrograms per liter: 3.29

Analysis Date: 11/20/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 12

Client Sample Identification Number 169.7-12

Collection date: 10/24/2020

Room 11

Micrograms per liter: 5.80

Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-0 13

Client Sample Identification Number 169.7-13

Collection date: 10/24/2020

3 Grade Girl's Lavatory Left

Micrograms per liter: 2.45

Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-14

Client Sample Identification Number 169.7-14

Collection date: 10/24/2020

3 Grade Girl's Lavatory Left Center

Micrograms per liter: 3.71

Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-15  
Client Sample Identification Number 169.7-15  
Collection date: 10/24/2020  
3 Grade Girl's Lavatory Right Center  
Micrograms per liter: 6.41  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-16  
Client Sample Identification Number 169.7-16  
Collection date: 10/24/2020  
3 Grade Girl's Lavatory Right  
Micrograms per liter: 1.11  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-17  
Client Sample Identification Number 169.7-17A  
Collection date: 10/24/2020  
Third Grade Hall Fountain  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-18  
Client Sample Identification Number 169.7-17B  
Collection date: 10/24/2020  
Third Grade Hall Fountain  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-19  
Client Sample Identification Number 169.7-18  
Collection date: 10/24/2020  
3 Grade Boy's Lavatory Left  
Micrograms per liter: 1.93  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-20  
Client Sample Identification Number 169.7-19  
Collection date: 10/24/2020  
3 Grade Boy's Lavatory Left Center  
Micrograms per liter: 2.39  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-21  
Client Sample Identification Number 169.7-20  
Collection date: 10/24/2020  
3 Grade Boy's Lavatory Right Center  
Micrograms per liter: 3.34  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-22  
Client Sample Identification Number 169.7-21  
Collection date: 10/24/2020  
3 Grade Boy's Lavatory Right  
Micrograms per liter: 1.16  
Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-23  
Client Sample Identification Number 169.7-22  
Collection date: 10/24/2020  
Room 25

Micrograms per liter: 3.22  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-24  
Client Sample Identification Number 169.7-23  
Collection date: 10/24/2020  
Room 26

Micrograms per liter: 2.50  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-25  
Client Sample Identification Number 169.7-24  
Collection date: 10/24/2020

Library Media Center  
Micrograms per liter: 2.16  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-26  
Client Sample Identification Number 169.7-26  
Collection date: 10/24/2020

Faculty Lavatory Right  
Micrograms per liter: 3.89  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-27  
Client Sample Identification Number 169.7-27A  
Collection date: 10/24/2020

Kindergarten 1 Wing Fountain  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-28  
Client Sample Identification Number 169.7-27B  
Collection date: 10/24/2020

Kindergarten 1 Wing Fountain  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-29  
Client Sample Identification Number 169.7-28  
Collection date: 10/24/2020

Room 14  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-30  
Client Sample Identification Number 169.7-29  
Collection date: 10/24/2020

Room 13  
Micrograms per liter: 2.84  
Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-31  
Client Sample Identification Number 169.7-30  
Collection date: 10/24/2020  
Room 16

Micrograms per liter: 1.33  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-32  
Client Sample Identification Number 169.7-31  
Collection date: 10/24/2020  
Room 15

Micrograms per liter: 2.59  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-33  
Client Sample Identification Number 169.7-33  
Collection date: 10/24/2020  
Room 19

Micrograms per liter: 1.41  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-33  
Client Sample Identification Number 169.7-33  
Collection date: 10/24/2020  
Room 19

Micrograms per liter: 1.41  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-34  
Client Sample Identification Number 169.7-34  
Collection date: 10/24/2020  
Room 20

Micrograms per liter: 2.92  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-35  
Client Sample Identification Number 169.7-35  
Collection date: 10/24/2020  
Room 19

Micrograms per liter: 4.58  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-36  
Client Sample Identification Number 169.7-36  
Collection date: 10/24/2020  
Room 22

Micrograms per liter: 4.26  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-37  
Client Sample Identification Number 169.7-37  
Collection date: 10/24/2020  
Room 21

Micrograms per liter: 1.39  
Analysis Date: 11/23/2020



Laboratory Sample Number: 20-10-0 6 1 3 0-38  
Client Sample Identification Number 169.7-38  
Collection date: 10/24/2020  
Room 24

Micrograms per liter: 8.56  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-39  
Client Sample Identification Number 169.7-39  
Collection date: 10/24/2020  
Room 23

Micrograms per liter: 3.97  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-40  
Client Sample Identification Number 169.7-40  
Collection date: 10/24/2020

Art Room Front Left  
Micrograms per liter: 9.45  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-41  
Client Sample Identification Number 169.7-41  
Collection date: 10/24/2020

Art Room Front Center  
Micrograms per liter: 3.29  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-42  
Client Sample Identification Number 169.7-42  
Collection date: 10/24/2020

Art Room Front Right  
Micrograms per liter: 1.27  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-43  
Client Sample Identification Number 169.7-43  
Collection date: 10/24/2020

Art Room Rear Left  
Micrograms per liter: 1.06  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-44  
Client Sample Identification Number 169.7-44  
Collection date: 10/24/2020

Art Room Rear Center  
Micrograms per liter: 1.74  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-45  
Client Sample Identification Number 169.7-45  
Collection date: 10/24/2020

Art Room Rear Right  
Micrograms per liter: 4.70  
Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-46  
Client Sample Identification Number 169.7-46  
Collection date: 10/24/2020  
Women's Lavatory by Main Office  
Micrograms per liter: 4.65  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-47  
Client Sample Identification Number 169.7-47  
Collection date: 10/24/2020  
Nurse 138 Main Left  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-48  
Client Sample Identification Number 169.7-48  
Collection date: 10/24/2020  
Nurse 138 Main Left  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-49  
Client Sample Identification Number 169.7-49  
Collection date: 10/24/2020  
Nurse 138 Main Right  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-50  
Client Sample Identification Number 169.7-50  
Collection date: 10/24/2020  
Nurse 138 Exam Room  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-51  
Client Sample Identification Number 169.7-51  
Collection date: 10/24/2020  
Nurse 138 Lavatory  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-52  
Client Sample Identification Number 169.7-52  
Collection date: 10/24/2020  
Boy's Lavatory by Nurse  
Micrograms per liter: 1.02  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-53  
Client Sample Identification Number 169.7-53  
Collection date: 10/24/2020  
Occupational Therapy Physical Therapy Room  
Micrograms per liter: 3.47  
Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-54  
Client Sample Identification Number 169.7-54  
Collection date: 10/24/2020  
Men's Physical Education Office  
Micrograms per liter: 8.13  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-55  
Client Sample Identification Number 169.7-55  
Collection date: 10/24/2020  
English as a New Language Room  
Micrograms per liter: 4.41  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-56  
Client Sample Identification Number 169.7-56  
Collection date: 10/24/2020  
Women's Physical Education Office  
Micrograms per liter: 3.57  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-57  
Client Sample Identification Number 169.7-57  
Collection date: 10/24/2020  
Outdoor Restroom  
Micrograms per liter: 1.41  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-33  
Client Sample Identification Number 169.7-33  
Collection date: 10/24/2020  
Room 19  
Micrograms per liter: 17.2  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-58  
Client Sample Identification Number 169.7-58  
Collection date: 10/24/2020  
Custodian's Office  
Micrograms per liter: 6.33  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-59  
Client Sample Identification Number 169.7-59  
Collection date: 10/24/2020  
Kitchen Handwash  
Micrograms per liter: 8.52  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-60  
Client Sample Identification Number 169.7-60  
Collection date: 10/24/2020  
Kitchen Prep Table Single Bay  
Micrograms per liter: 9.06  
Analysis Date: 11/23/2020

Laboratory Sample Number: 20-10-0 6 1 3 0-61  
Client Sample Identification Number 169.7-61  
Collection date: 10/24/2020  
Kitchen Pan Fill  
Micrograms per liter: 25.7  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-62  
Client Sample Identification Number 169.7-62  
Collection date: 10/24/2020  
Kitchen 3 Bay Left Sink  
Micrograms per liter: 13.2  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-63  
Client Sample Identification Number 169.7-63  
Collection date: 10/24/2020  
Kitchen 3 Bay Right  
Micrograms per liter: 3.19  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-64  
Client Sample Identification Number 169.7-64  
Collection date: 10/24/2020  
Kitchen 2 Bay  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-65  
Client Sample Identification Number 169.7-65  
Collection date: 10/24/2020  
Kitchen Dish Sprayer  
Micrograms per liter: 3.07  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-66  
Client Sample Identification Number 169.7-66  
Collection date: 10/24/2020  
Kitchen Lavatory  
Micrograms per liter: 3.09  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-67  
Client Sample Identification Number 169.7-67A  
Collection date: 10/24/2020  
Cafeteria  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020  
Laboratory Sample Number: 20-10-0 6 1 3 0-68  
Client Sample Identification Number 169.7-67B  
Collection date: 10/24/2020  
Cafeteria  
Micrograms per liter: less than 1.00  
Analysis Date: 11/23/2020

Method: SM 3 1 1 3 B – 2 0 1 0

Analyst: Jennalee Hertzler

Accreditation Number: New York 1 1 7 1 4

Reviewed and Authorized Signatory by Melissa Kanode; Quality Assurance Quality Control Clerk

Sample results denoted with a "less than" sign contain less than the reporting limit which is 1 part per billion.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 parts per billion. The results herein conform to National Environmental Laboratory Accreditation Conference standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

## 1.5 Laboratory Certifications

New York State Department of Health Wadsworth Center

Certificate of Approval for Laboratory Service

issued in accordance with and pursuant to section 502 Public Health Law of New York state

Expires 12:01 AM April 01, 2021

Issued April 01, 2020

New York Laboratory Identification Number: 1 1 7 1 4

Ms. Julie Dickerson

Environmental Hazards Services, L.L.C.

7469 Whitepine Road

North Chesterfield, VA 23237

is hereby approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category Environmental Analyses Potable Water.

All approved analytes are listed below:

Metals 1

Copper, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Lead, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Serial Number: 6 1 5 1 4

Property of the New York State Department of Health. Certificates are valid only at the address shown; must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518)485-5570 to verify the laboratory's accreditation status.

## 1.6 Chains of Custody

Chain of Custody Document submitted to Environmental Hazards Services, L.L.C.

Stohl Job Number: 2 0 2 0 L -169 .7

Lancaster Central School District

Contact: Michael Bryniarski

John A. Sciole Elementary

86 Alys Drive, Depew, New York 14043

Lead: Water by S M 19, 21-23 3 1 1 3 B (-04, -10)

Turnaround 20 days

Sample Number 169 .7-1	Room 2	Outlet Type Sink	Time: 12:35
Sample Number 169 .7-2	Room 1	Outlet Type Sink	Time 12:36
Sample Number 169 .7-3	Room 3	Outlet Type Sink	Time 12:37
Sample Number 169 .7-4	Room 3	Outlet Type Sink	Time 12:38
Sample Number 169 .7-5	Room 6	Outlet Type Sink	Time 12:39
Sample Number 169 .7-6	Room 5	Outlet Type Sink	Time 12:40
Sample Number 169 .7-7	Room 8	Outlet Type Sink	Time 12:41
Sample Number 169 .7-8	Room 7	Outlet Type Sink	Time 12:42
Sample Number 169 .7-9	Room 10	Outlet Type Sink	Time 12:43

Sample Number 169.7-10	Room 9	Outlet Type Sink	Time	12:44
Sample Number 169.7-11	Room 12	Outlet Type Sink	Time	12:45
Sample Number 169.7-12	Room 11	Outlet Type Sink	Time	12:46
Sample Number 169.7-13	3 Grade Girl's Lavatory Left	Outlet Type Sink	Time	12:47
Sample Number 169.7-14	3 Grade Girl's Lavatory Left Center	Outlet Type Sink	Time	12:48
Sample Number 169.7-15	3 Grade Girl Lavatory Right Center	Outlet Type Sink	Time	12:49
Sample Number 169.7-16	3 Grade Girl's Lavatory Right	Outlet Type Sink	Time	12:50
Sample Number 169.7-17	Third Grade Hall Fountain	Outlet Type D F A	Time	12:51
Sample Number 169.7-17B	Third Grade Hall Fountain	Outlet Type D F B	Time	12:52
Sample Number 169.7-18	3 Grade Boy's Lavatory Left	Outlet Type Sink	Time	12:53
Sample Number 169.7-19	3 Grade Boy's Lavatory Left Center	Outlet Type Sink	Time	12:54
Sample Number 169.7-20	3 Grade Boy's Lavatory Right Center	Outlet Type Sink	Time	12:55
Sample Number 169.7-21	3 Grade Boy's Lavatory Right	Outlet Type Sink	Time	12:56
Sample Number 169.7-22	Room 25	Outlet Type Sink	Time	12:57
Sample Number 169.7-23	Room 26	Outlet Type Sink	Time	12:58
Sample Number 169.7-24	Library Media Center	Outlet Type Sink	Time	12:59
Sample Number 169.7-25	Faculty Lavatory Left	Outlet Type Sink	Time	13:00
Sample Number 169.7-26	Faculty Lavatory Right	Outlet Type Sink	Time	13:01
Sample Number 169.7-27A	Kindergarten 1 Wing Fountain	Outlet Type D F A	Time	13:02
Sample Number 169.7-27B	Kindergarten 1 Wing Fountain	Outlet Type D F B	Time	13:03
Sample Number 169.7-28	Room 14	Outlet Type Sink	Time	13:04
Sample Number 169.7-29	Room 13	Outlet Type Sink	Time	13:05
Sample Number 169.7-30	Room 16	Outlet Type Sink	Time	13:06
Sample Number 169.7-31	Room 15	Outlet Type Sink	Time	13:07
Sample Number 169.7-32	Room 18	Outlet Type Sink	Time	13:08
Sample Number 169.7-33	Room 19	Outlet Type Sink	Time	13:09
Sample Number 169.7-34	Room 20	Outlet Type Sink	Time	13:10
Sample Number 169.7-35	Room 19	Outlet Type Sink	Time	13:11
Sample Number 169.7-36	Room 22	Outlet Type Sink	Time	13:12
Sample Number 169.7-37	Room 21	Outlet Type Sink	Time	13:13
Sample Number 169.7-38	Room 24	Outlet Type Sink	Time	13:14
Sample Number 169.7-39	Room 23	Outlet Type Sink	Time	13:15
Sample Number 169.7-40	Art Room Front Left	Outlet Type Sink	Time	13:16
Sample Number 169.7-41	Art Room Front Center	Outlet Type Sink	Time	13:17
Sample Number 169.7-42	Art Room Front Right	Outlet Type Sink	Time	13:18
Sample Number 169.7-43	Art Room Rear Left	Outlet Type Sink	Time	13:19
Sample Number 169.7-44	Art Room Rear Center	Outlet Type Sink	Time	13:20
Sample Number 169.7-45	Art Room Rear Right	Outlet Type Sink	Time	13:21
Sample Number 169.7-46	Women's Lavatory by Main Office	Outlet Type Sink	Time	13:22
Sample Number 169.7-47	Nurse 138 Main Left	Outlet Type Sink	Time	13:23
Sample Number 169.7-48	Nurse 138 Main Left	Outlet Type Bubbler	Time	13:24
Sample Number 169.7-49	Nurse 138 Main Right	Outlet Type Sink	Time	13:25
Sample Number 169.7-50	Nurse 138 Exam Room	Outlet Type Sink	Time	13:26
Sample Number 169.7-51	Nurse 138 Lavatory	Outlet Type Sink	Time	13:27
Sample Number 169.7-52	Boy's Lavatory by Nurse	Outlet Type Sink	Time	13:28
Sample Number 169.7-53	OT PT Room	Outlet Type Sink	Time	13:29
Sample Number 169.7-54	Men's Physical Education Office	Outlet Type Sink	Time	13:30
Sample Number 169.7-55	English as a New Language Room	Outlet Type Sink	Time	13:31

Sample Number 169.7-56	Women's Physical Education Office	Outlet Type Sink	Time	13:32
Sample Number 169.7-57	Outdoor restroom	Outlet Type Sink	Time	13:33
Sample Number 169.7-58	Custodian's Office	Outlet Type Sink	Time	13:34
Sample Number 169.7-59	Kitchen Handwash	Outlet Type Sink	Time	13:35
Sample Number 169.7-60	Kitchen Prep Table Single Bay	Outlet Type Sink	Time	13:36
Sample Number 169.7-61	Kitchen Pan Fill	Outlet Type Sink	Time	13:37
Sample Number 169.7-62	Kitchen 3 Bay Left Sink	Outlet Type Sink	Time	13:38
Sample Number 169.7-63	Kitchen 3 Bay Right	Outlet Type Sink	Time	13:39
Sample Number 169.7-64	Kitchen 2 Bay	Outlet Type Sink	Time	13:40
Sample Number 169.7-65	Kitchen Dish Sprayer	Outlet Type Sink	Time	13:41
Sample Number 169.7-66	Kitchen Lavatory	Outlet Type Sink	Time	13:42
Sample Number 169.7-67A	Cafeteria	Outlet Type Sink	Time	13:43
Sample Number 169.7-67B	Cafeteria	Outlet Type Sink	Time	13:44

Sample Number 169.7-25 and Sample Number 169.7-32 were received empty signature 10/30/2020

Please e-mail lab results to [labs@stohlenvironment.com](mailto:labs@stohlenvironment.com) If checked, also e-mail results to:  
[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: C. Schultz and P. Nichols Stohl Environmental 10/24/2020

Relinquished By: Eric Henderson Jr. 10/26/2020

Received (Name, Laboratory): signature 10/29/20 at 6:40pm

Sample Login (Name, Laboratory): signature 11/17/2020 at 5:36pm

Analysis (Name, Laboratory): J. Hertzler 11/23/2020 at 3:35pm

Archived, Released: signature 11/24/2020 at 1:00pm