

Water Sampling – William Street School Final Report

Stohl Environmental
3860 California Road Orchard Park, New York 14127
Phone: 716-312-0070 Fax: 716-312-8092
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski
Director of Facilities
Lancaster Central School District
177 Central Avenue
Lancaster, NY 14086

Regarding: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:
William Street School – 5201 William Street, Lancaster, New York.

This report is prepared to assist the District in complying with the requirements of New York State regulations, Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the New York State "Action Level of 15 parts per billion (p.p.b)".

The Investigation and Sampling was performed on October 24, 2020. The Protocol for the Investigation followed the requirements of New York State regulations as well as United States Environmental Protection Agency Technical Guidance "3 T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 6 sources of potable water in William Street School has been identified as having lead concentration in water above the New York State Action Level of 15 parts per billion. To comply with New York State regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

"Signature of Eric Henderson Jr."
Senior Project Manager

Investigation and Sampling of Sources of Potable Water for Lead Concentrations Prepared for: Lancaster Central School District Prepared by:

Stohl Environmental
3860 California Road
Orchard Park, New York 14127
Phone (716) 312-0070 Fax (716) 312-8092
www.stohlenvironmental.com

Conditions as of October 24, 2020

Summary Tabulation Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under New York State
- 1.4. Regulations Laboratory Analytical Reports by
- 1.5. Building Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

William Street School – 5201 William Street, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Transportation Department. Outlets are defined in New York State regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with New York State regulations, Subpart 67 -4: Lead Testing in School Drinking Water, and the Environmental Protection Agency guidance document, "3Ts for Reducing Lead in Drinking Water in Schools", Stohl Environmental's protocol can be summarized as follows:

First-draw samples of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the New York State Department of Health's Environmental Laboratory Approval Program (E L A P).

1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw and Confirmatory Samples:

The date of sample event on 10/24/2020 the William Street School had a total of 214 samples collected. The First draw samples had 208 samples at or below action level of 15 parts per billion and 6 samples above action level of 15 parts per billion.

The date of sample event on 10/24/2020 the William Street School had confirmatory samples at or below action level of 15 parts per billion and above action level of 15 parts per billion that are not applicable.

Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

Listings of Outlet Requiring Remediation

Locations of Outlets analyzed above New York State level of 15 parts per billion based upon analysis of first draw samples:

Sample Number 169.3-16	Serving Hand Wash	Fixture	Sink	Laboratory Analysis parts per billion	22.8
Sample Number 169.3-35	B106 Sprayer	Fixture	Sink	Laboratory Analysis parts per billion	16.8
Sample Number 169.3-43	B112 Band Lesson	Fixture	Sink	Laboratory Analysis parts per billion	28.3
Sample Number 169.3-123	B206 Sprayer	Fixture	Sink	Laboratory Analysis parts per billion	66.4
Sample Number 169.3-127	B204 Front	Fixture	Sink	Laboratory Analysis parts per billion	121
Sample Number 169.3-150	B218	Fixture	Sink	Laboratory Analysis parts per billion	not applicable
Sample Number 169.3-187	D232 Sprayer	Fixture	Sink	Laboratory Analysis parts per billion	18.6

Sample 169.3-150 was not analyzed. The Laboratory received the sample empty and was not able to be analyzed. Location should be resampled and analyzed at a later date.

1.3 Response Actions Required Under New York State Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the New York State Action Level, regulations require:

- (a) Prohibit use of the outlet until:
 - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
 - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, LLC
7469 Whitepine Road
Richmond, VA 23237

Telephone: 800-347-4010

Lead in Drinking Water Analysis Report

Report Number: 20 - 10 - 0 6 1 2 8

Client: Stohl Environmental 3860 California Road Orchard Park, NY 14127

Received Date: 10/29/2020

Reported Date: 11/24/2020

Sampled By: C. Schultz and P. Nichols

Tech Certification Number:

Project Test Address: 2 0 2 0 L-169 .3; William Street School; 5201 William Street.; Lancaster, NY 14086

Client Number: 33 - 5 9 8 0

Fax Number: 716-312-8092

Laboratory Results

Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 1

Client Sample Identification Number 169.3-1

Collection date: 10/24/2020

Loading Dock Left Lavatory

Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 2

Client Sample Identification Number 169.3-2

Collection date: 10/24/2020

Loading Dock Right Lavatory

Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 3

Client Sample Identification Number 169.3-3

Collection date: 10/24/2020

Kitchen Handwash by Freezers

Micrograms per liter: 1.97

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 4

Client Sample Identification Number 169.3-4

Collection date: 10/24/2020

Kitchen 2 Bay

Micrograms per liter: less than 1.00

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 5

Client Sample Identification Number 169.3-5

Collection date: 10/24/2020

Kitchen Single Bay

Micrograms per liter: 1.41

Analysis Date: 11/19/2020

Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 6

Client Sample Identification Number 169.3-6

Collection date: 10/24/2020

Kitchen Handwash Corner

Micrograms per liter: 9.18
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 7
Client Sample Identification Number 169.3-7
Collection date: 10/24/2020
Kitchen Dish Sprayer
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 8
Client Sample Identification Number 169.3-8
Collection date: 10/24/2020
Kitchen Dish Single Bay
Micrograms per liter: 2.24
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 0 9
Client Sample Identification Number 169.3-9
Collection date: 10/24/2020
Kitchen Dish 2 Bay
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 10
Client Sample Identification Number 169.3-10
Collection date: 10/24/2020
Kitchen Kettle
Micrograms per liter: 7.81
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 11
Client Sample Identification Number 169.3-11
Collection date: 10/24/2020
Kitchen Single by Coffee
Micrograms per liter: 5.57
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 12
Client Sample Identification Number 169.3-12
Collection date: 10/24/2020
Dishwasher Left
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 13
Client Sample Identification Number 169.3-13
Collection date: 10/24/2020
Dishwasher Right
Micrograms per liter: 1.40
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 14
Client Sample Identification Number 169.3-14
Collection date: 10/24/2020
Dish Sprayer by Cafeteria

Micrograms per liter: 2.90
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 15
Client Sample Identification Number 169.3-15
Collection date: 10/24/2020
Dish Room Handwash
Micrograms per liter: 3.01
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 16
Client Sample Identification Number 169.3-16
Collection date: 10/24/2020
Serving Handwash
Micrograms per liter: 22.8
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 17
Client Sample Identification Number 169.3-17
Collection date: 10/24/2020
Serving Handwash by Refrigerators
Micrograms per liter: 2.26
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 18
Client Sample Identification Number 169.3-18
Collection date: 10/24/2020
Handwash by Stove
Micrograms per liter: 12.7
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 19
Client Sample Identification Number 169.3-19
Collection date: 10/24/2020
Handwash by Office
Micrograms per liter: 1.50
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 20
Client Sample Identification Number 169.3-20
Collection date: 10/24/2020
Kitchen Ice Machine
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 21
Client Sample Identification Number 169.3-21A
Collection date: 10/24/2020
Cafeteria
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 22
Client Sample Identification Number 169.3-21B
Collection date: 10/24/2020
Cafeteria

Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 23
Client Sample Identification Number 169.3-22
Collection date: 10/24/2020
Girls Lavatory B1 Left
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 24
Client Sample Identification Number 169.3-23
Collection date: 10/24/2020
Girls Lavatory B1 Center
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 25
Client Sample Identification Number 169.3-24
Collection date: 10/24/2020
Girls Lavatory B1 Right
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 26
Client Sample Identification Number 169.3-25
Collection date: 10/24/2020
Boys Lavatory B1 Left
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 27
Client Sample Identification Number 169.3-26
Collection date: 10/24/2020
Boys Lavatory B1 Center
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 28
Client Sample Identification Number 169.3-27
Collection date: 10/24/2020
Boys Lavatory B1 Right
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 29
Client Sample Identification Number 169.3-28A
Collection date: 10/24/2020
B1 Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 30
Client Sample Identification Number 169.3-28B
Collection date: 10/24/2020
B1 Fountain

Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 31
Client Sample Identification Number 169.3-29
Collection date: 10/24/2020
B 109
Micrograms per liter: less than 1.00
Analysis Date: 11/19/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 32
Client Sample Identification Number 169.3-30
Collection date: 10/24/2020
B 108
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 33
Client Sample Identification Number 169.3-31
Collection date: 10/24/2020
B 107
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 34
Client Sample Identification Number 169.3-32A
Collection date: 10/24/2020
B Common Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 35
Client Sample Identification Number 169.3-32B
Collection date: 10/24/2020
B Common Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 36
Client Sample Identification Number 169.3-33
Collection date: 10/24/2020
B 106 Front
Micrograms per liter: 4.17
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 37
Client Sample Identification Number 169.3-34
Collection date: 10/24/2020
B 106 Rear
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 38
Client Sample Identification Number 169.3-35
Collection date: 10/24/2020
B 106 Sprayer

Micrograms per liter: 16.8
Analysis Date: 11/13/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 39
Client Sample Identification Number 169.3-36
Collection date: 10/24/2020
Left Lavatory Outside B105
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 40
Client Sample Identification Number 169.3-37
Collection date: 10/24/2020
B 105 Faculty
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 41
Client Sample Identification Number 169.3-38
Collection date: 10/24/2020
Right lavatory Outside B105
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 42
Client Sample Identification Number 169.3-39
Collection date: 10/24/2020
B 104
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 43
Client Sample Identification Number 169.3-40
Collection date: 10/24/2020
B 103
Micrograms per liter: 6.28
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 44
Client Sample Identification Number 169.3-41
Collection date: 10/24/2020
B 102
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 45
Client Sample Identification Number 169.3-42
Collection date: 10/24/2020
B 101
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 46
Client Sample Identification Number 169.3-43
Collection date: 10/24/2020
B 112 Band Lesson

Micrograms per liter: 28.3
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 47
Client Sample Identification Number 169.3-44
Collection date: 10/24/2020
B 113 Library Classroom
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 48
Client Sample Identification Number 169.3-45
Collection date: 10/24/2020
D 117 Main Office Kitchen
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 49
Client Sample Identification Number 169.3-46
Collection date: 10/24/2020
D 117 Main Office Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 50
Client Sample Identification Number 169.3-47
Collection date: 10/24/2020
C 132 Chorus
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 51
Client Sample Identification Number 169.3-48
Collection date: 10/24/2020
C 133 Sink
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 52
Client Sample Identification Number 169.3-49
Collection date: 10/24/2020
C 133 Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 53
Client Sample Identification Number 169.3-50
Collection date: 10/24/2020
C1 Women's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 54
Client Sample Identification Number 169.3-51
Collection date: 10/24/2020
C1 Men's Faculty Lavatory

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 55
Client Sample Identification Number 169.3-52
Collection date: 10/24/2020
C1 Girls Gang Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 56
Client Sample Identification Number 169.3-53
Collection date: 10/24/2020
C1 Girls Gang Left Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 57
Client Sample Identification Number 169.3-54
Collection date: 10/24/2020
C1 Girls Gang Right Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 58
Client Sample Identification Number 169.3-56
Collection date: 10/24/2020
C1 Boys Gang Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 59
Client Sample Identification Number 169.3-57
Collection date: 10/24/2020
C1 Boys Gang Left Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 60
Client Sample Identification Number 169.3-58
Collection date: 10/24/2020
C1 Boys Gang Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 61
Client Sample Identification Number 169.3-59
Collection date: 10/24/2020
C1 Boys Gang Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 62
Client Sample Identification Number 169.3-60
Collection date: 10/24/2020
C1 Boys Side Fountain Left

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 63
Client Sample Identification Number 169.3-61
Collection date: 10/24/2020
C1 Boys Side Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 64
Client Sample Identification Number 169.3-62
Collection date: 10/24/2020
C1 Girls Side Fountain Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 65
Client Sample Identification Number 169.3-63
Collection date: 10/24/2020
C1 Girls Side Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 66
Client Sample Identification Number 169.3-64
Collection date: 10/24/2020
C 146
Micrograms per liter: 6.25
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 67
Client Sample Identification Number 169.3-65
Collection date: 10/24/2020
C 145
Micrograms per liter: 2.16
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 68
Client Sample Identification Number 169.3-66
Collection date: 10/24/2020
C 144
Micrograms per liter: 1.98
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 69
Client Sample Identification Number 169.3-67
Collection date: 10/24/2020
C 143
Micrograms per liter: 2.34
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 70
Client Sample Identification Number 169.3-68
Collection date: 10/24/2020
C 142

Micrograms per liter: 1.48
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 71
Client Sample Identification Number 169.3-69
Collection date: 10/24/2020
C 141
Micrograms per liter: 1.18
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 72
Client Sample Identification Number 169.3-70
Collection date: 10/24/2020
C 139
Micrograms per liter: 2.84
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 73
Client Sample Identification Number 169.3-71
Collection date: 10/24/2020
C 138
Micrograms per liter: 3.29
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 74
Client Sample Identification Number 169.3-72
Collection date: 10/24/2020
C 137
Micrograms per liter: 2.35
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 75
Client Sample Identification Number 169.3-73
Collection date: 10/24/2020
C 136
Micrograms per liter: 1.39
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 76
Client Sample Identification Number 169.3-74
Collection date: 10/24/2020
C 135
Micrograms per liter: 2.44
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 77
Client Sample Identification Number 169.3-75
Collection date: 10/24/2020
C 134
Micrograms per liter: 3.61
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 78
Client Sample Identification Number 169.3-76
Collection date: 10/24/2020
D 118 Nurse Main

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 79
Client Sample Identification Number 169.3-77
Collection date: 10/24/2020
D 118 Nurse Exam
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 80
Client Sample Identification Number 169.3-78
Collection date: 10/24/2020
D118 Nurse Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 81
Client Sample Identification Number 169.3-79
Collection date: 10/24/2020
Girls Pool Locker Room Left
Micrograms per liter: 2.34
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 82
Client Sample Identification Number 169.3-80
Collection date: 10/24/2020
Girls Pool Locker Room Center
Micrograms per liter: 1.67
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 83
Client Sample Identification Number 169.3-81
Collection date: 10/24/2020
Girls Pool Locker Room Right
Micrograms per liter: 1.75
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 84
Client Sample Identification Number 169.3-82
Collection date: 10/24/2020
Boys Locker Room Left
Micrograms per liter: 1.01
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 85
Client Sample Identification Number 169.3-83
Collection date: 10/24/2020
Boys Pool Locker Room Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 86
Client Sample Identification Number 169.3-84
Collection date: 10/24/2020
Boys Pool Locker Room Right

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 87
Client Sample Identification Number 169.3-85
Collection date: 10/24/2020
New Gym Girl Side Fountain Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 88
Client Sample Identification Number 169.3-86
Collection date: 10/24/2020
New Gym Girl Side Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 89
Client Sample Identification Number 169.3-87
Collection date: 10/24/2020
New Gym Boy Side Fountain Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 90
Client Sample Identification Number 169.3-88
Collection date: 10/24/2020
New Gym Boy Side Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 91
Client Sample Identification Number 169.3-90
Collection date: 10/24/2020
Old Gym Boys Locker Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 92
Client Sample Identification Number 169.3-91
Collection date: 10/24/2020
Old Gym Boys Locker Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 93
Client Sample Identification Number 169.3-92
Collection date: 10/24/2020
Old Gym Boys Coach Office
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 94
Client Sample Identification Number 169.3-93
Collection date: 10/24/2020
Old Gym Girls Locker Left

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 95
Client Sample Identification Number 169.3-94
Collection date: 10/24/2020
Old Gym Girls Locker Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 96
Client Sample Identification Number 169.3-95
Collection date: 10/24/2020
Old Gym Girls Locker Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 97
Client Sample Identification Number 169.3-96
Collection date: 10/24/2020
Old Gym Girls Coach Office
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 98
Client Sample Identification Number 169.3-97A
Collection date: 10/24/2020
Old Gym Girls Side Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-0 99
Client Sample Identification Number 169.3-97B
Collection date: 10/24/2020
Old Gym Girls Side Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8- 100
Client Sample Identification Number 169.3-98
Collection date: 10/24/2020
D Boys Gang Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8- 101
Client Sample Identification Number 169.3-99
Collection date: 10/24/2020
D Boys Gang Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8- 102
Client Sample Identification Number 169.3-100
Collection date: 10/24/2020
D Boys Gang Right

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8- 103
Client Sample Identification Number 169.3-101
Collection date: 10/24/2020
D Girls Gang Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8- 104
Client Sample Identification Number 169.3-102
Collection date: 10/24/2020
D Girls Gang Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8- 105
Client Sample Identification Number 169.3-103
Collection date: 10/24/2020
D Girls Gang Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-106
Client Sample Identification Number 169.3-104A
Collection date: 10/24/2020
D Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-107
Client Sample Identification Number 169.3-104B
Collection date: 10/24/2020
D Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-108
Client Sample Identification Number 169.3-105
Collection date: 10/24/2020
D 122
Micrograms per liter: 9.90
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-109
Client Sample Identification Number 169.3-106
Collection date: 10/24/2020
D 123
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-110
Client Sample Identification Number 169.3-107
Collection date: 10/24/2020
D 124

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-111
Client Sample Identification Number 169.3-108A
Collection date: 10/24/2020
D Rear Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-112
Client Sample Identification Number 169.3-108B
Collection date: 10/24/2020
D Rear Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-113
Client Sample Identification Number 169.3-109
Collection date: 10/24/2020
D 125
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-114
Client Sample Identification Number 169.3-110
Collection date: 10/24/2020
D Men's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-115
Client Sample Identification Number 169.3-111
Collection date: 10/24/2020
D 126
Micrograms per liter: 2.02
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-116
Client Sample Identification Number 169.3-112
Collection date: 10/24/2020
D Women's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-117
Client Sample Identification Number 169.3-113
Collection date: 10/24/2020
D 127
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-118
Client Sample Identification Number 169.3-114
Collection date: 10/24/2020
D 128

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-119
Client Sample Identification Number 169.3-115
Collection date: 10/24/2020
D 129
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-120
Client Sample Identification Number 169.3-116
Collection date: 10/24/2020
D 130
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-121
Client Sample Identification Number 169.3-117
Collection date: 10/24/2020
B 210
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-122
Client Sample Identification Number 169.3-118
Collection date: 10/24/2020
B 209
Micrograms per liter: 1.03
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-123
Client Sample Identification Number 169.3-119
Collection date: 10/24/2020
B 208
Micrograms per liter: 1.37
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-124
Client Sample Identification Number 169.3-120A
Collection date: 10/24/2020
B Rear Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-125
Client Sample Identification Number 169.3-120B
Collection date: 10/24/2020
B Rear Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-126
Client Sample Identification Number 169.3-121
Collection date: 10/24/2020
B 206 Front

Micrograms per liter: 12.1
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-127
Client Sample Identification Number 169.3-122
Collection date: 10/24/2020
B 206 Rear
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-128
Client Sample Identification Number 169.3-123
Collection date: 10/24/2020
B 206 Sprayer
Micrograms per liter: 66.4
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-129
Client Sample Identification Number 169.3-124
Collection date: 10/24/2020
B Women's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-130
Client Sample Identification Number 169.3-125
Collection date: 10/24/2020
B 205
Micrograms per liter: 1.23
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-131
Client Sample Identification Number 169.3-126
Collection date: 10/24/2020
B Men's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-132
Client Sample Identification Number 169.3-127
Collection date: 10/24/2020
B 204 Front
Micrograms per liter: 121
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-133
Client Sample Identification Number 169.3-128
Collection date: 10/24/2020
B 204 Rear
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-134
Client Sample Identification Number 169.3-130
Collection date: 10/24/2020
B 203

Micrograms per liter: 1.33
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-135
Client Sample Identification Number 169.3-131
Collection date: 10/24/2020

B 202

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-136
Client Sample Identification Number 169.3-132
Collection date: 10/24/2020

B 201

Micrograms per liter: 1.28
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-137
Client Sample Identification Number 169.3-133
Collection date: 10/24/2020

B2 Fountain

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-138
Client Sample Identification Number 169.3-134
Collection date: 10/24/2020

B2 Boys Gang Left

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-139
Client Sample Identification Number 169.3-135
Collection date: 10/24/2020

B2 Boys Gang Center

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-140
Client Sample Identification Number 169.3-136
Collection date: 10/24/2020

B2 Boys Gang Right

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-141
Client Sample Identification Number 169.3-137
Collection date: 10/24/2020

B2 Girls Gang Lavatory Left

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-142
Client Sample Identification Number 169.3-139
Collection date: 10/24/2020

B2 Girls Gang Lavatory Right

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-143
Client Sample Identification Number 169.3-140
Collection date: 10/24/2020
B 200
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-144
Client Sample Identification Number 169.3-141
Collection date: 10/24/2020
B 211
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-145
Client Sample Identification Number 169.3-142
Collection date: 10/24/2020
B 213
Micrograms per liter: 2.24
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-146
Client Sample Identification Number 169.3-143
Collection date: 10/24/2020
B 214
Micrograms per liter: 1.74
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-147
Client Sample Identification Number 169.3-144
Collection date: 10/24/2020
B 215 B Center Front
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-148
Client Sample Identification Number 169.3-145
Collection date: 10/24/2020
B 215 B Center Rear
Micrograms per liter: 3.14
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-149
Client Sample Identification Number 169.3-146
Collection date: 10/24/2020
B 215 B Corner Handwash
Micrograms per liter: 1.21
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-150
Client Sample Identification Number 169.3-147
Collection date: 10/24/2020
B 215 A Left Front

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-151
Client Sample Identification Number 169.3-148
Collection date: 10/24/2020
B 215 A Right Rear
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-152
Client Sample Identification Number 169.3-149
Collection date: 10/24/2020
B 217
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-153
Client Sample Identification Number 169.3-151
Collection date: 10/24/2020
C2 Girls Side Fountain Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-154
Client Sample Identification Number 169.3-152
Collection date: 10/24/2020
C2 Girls Side Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-155
Client Sample Identification Number 169.3-153
Collection date: 10/24/2020
C 253
Micrograms per liter: 5.64
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-156
Client Sample Identification Number 169.3-154
Collection date: 10/24/2020
C 252
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-157
Client Sample Identification Number 169.3-155
Collection date: 10/24/2020
C 251
Micrograms per liter: 3.88
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-158
Client Sample Identification Number 169.3-156
Collection date: 10/24/2020
C 250

Micrograms per liter: 1.05
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-159
Client Sample Identification Number 169.3-157
Collection date: 10/24/2020
C 249
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-160
Client Sample Identification Number 169.3-158
Collection date: 10/24/2020
C 248
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-161
Client Sample Identification Number 169.3-159
Collection date: 10/24/2020
C 246
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-162
Client Sample Identification Number 169.3-160
Collection date: 10/24/2020
C 245
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-163
Client Sample Identification Number 169.3-161
Collection date: 10/24/2020
C 244
Micrograms per liter: 3.65
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-164
Client Sample Identification Number 169.3-162
Collection date: 10/24/2020
C 243
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-165
Client Sample Identification Number 169.3-163
Collection date: 10/24/2020
C 242
Micrograms per liter: 2.58
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-166
Client Sample Identification Number 169.3-164
Collection date: 10/24/2020
C 241

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-167
Client Sample Identification Number 169.3-165
Collection date: 10/24/2020
C2 Boys Side Fountain Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-168
Client Sample Identification Number 169.3-166
Collection date: 10/24/2020
C2 Boys Side Fountain Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-169
Client Sample Identification Number 169.3-167
Collection date: 10/24/2020
C2 Boys Lavatory Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-170
Client Sample Identification Number 169.3-168
Collection date: 10/24/2020
C2 Boys lavatory Left Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-171
Client Sample Identification Number 169.3-169
Collection date: 10/24/2020
C2 Boys lavatory Right Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-172
Client Sample Identification Number 169.3-170
Collection date: 10/24/2020
C2 Boys Lavatory Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-173
Client Sample Identification Number 169.3-171
Collection date: 10/24/2020
C2 Girls Lavatory Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-173
Client Sample Identification Number 169.3-171
Collection date: 10/24/2020
C2 Girls Lavatory Left

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-174
Client Sample Identification Number 169.3-172
Collection date: 10/24/2020
C2 Girls Lavatory Left Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-175
Client Sample Identification Number 169.3-173
Collection date: 10/24/2020
C2 Girls Lavatory Right Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-176
Client Sample Identification Number 169.3-174
Collection date: 10/24/2020
C2 Girls Lavatory Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-177
Client Sample Identification Number 169.3-175
Collection date: 10/24/2020
C2 Men's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-178
Client Sample Identification Number 169.3-176
Collection date: 10/24/2020
C2 Women's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-179
Client Sample Identification Number 169.3-177
Collection date: 10/24/2020
C 240 Front Middle
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-180
Client Sample Identification Number 169.3-178
Collection date: 10/24/2020
C2 Back Middle
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-181
Client Sample Identification Number 169.3-179
Collection date: 10/24/2020
C 239

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-182
Client Sample Identification Number 169.3-180
Collection date: 10/24/2020
C 219
Micrograms per liter: 2.48
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-183
Client Sample Identification Number 169.3-181
Collection date: 10/24/2020
D 228
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-184
Client Sample Identification Number 169.3-182
Collection date: 10/24/2020
D 229
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-185
Client Sample Identification Number 169.3-183
Collection date: 10/24/2020
D 230
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-186
Client Sample Identification Number 169.3-184A
Collection date: 10/24/2020
D Rear Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-187
Client Sample Identification Number 169.3-184B
Collection date: 10/24/2020
D Rear Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-188
Client Sample Identification Number 169.3-185
Collection date: 10/24/2020
D 232 Front
Micrograms per liter: 3.66
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-189
Client Sample Identification Number 169.3-186
Collection date: 10/24/2020
D 232 Rear

Micrograms per liter: 1.99
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-190
Client Sample Identification Number 169.3-187
Collection date: 10/24/2020
D 232 Sprayer
Micrograms per liter: 18.6
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-191
Client Sample Identification Number 169.3-188
Collection date: 10/24/2020
D Men's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-192
Client Sample Identification Number 169.3-189
Collection date: 10/24/2020
D 233
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-193
Client Sample Identification Number 169.3-190
Collection date: 10/24/2020
D Women's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-194
Client Sample Identification Number 169.3-191
Collection date: 10/24/2020
D 234 Front
Micrograms per liter: 8.94
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-195
Client Sample Identification Number 169.3-192
Collection date: 10/24/2020
D 234 Rear
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-196
Client Sample Identification Number 169.3-194
Collection date: 10/24/2020
D 235
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-197
Client Sample Identification Number 169.3-195
Collection date: 10/24/2020
D 236

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-198
Client Sample Identification Number 169.3-196
Collection date: 10/24/2020
D 237
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-199
Client Sample Identification Number 169.3-197A
Collection date: 10/24/2020
D2 Fountain
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-200
Client Sample Identification Number 169.3-197B
Collection date: 10/24/2020
D Women's Faculty Lavatory
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-201
Client Sample Identification Number 169.3-198
Collection date: 10/24/2020
D2 Boys Gang Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-202
Client Sample Identification Number 169.3-199
Collection date: 10/24/2020
D2 Boys Gang Center
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-203
Client Sample Identification Number 169.3-200
Collection date: 10/24/2020
D2 Boys Gang Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-204
Client Sample Identification Number 169.3-201
Collection date: 10/24/2020
D2 Girls Gang Left
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-205
Client Sample Identification Number 169.3-202
Collection date: 10/24/2020
D2 Girls Gang Center

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-206
Client Sample Identification Number 169.3-203
Collection date: 10/24/2020
D2 Girls Gang Right
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-207
Client Sample Identification Number 169.3-204
Collection date: 10/24/2020
D 238
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-208
Client Sample Identification Number 169.3-205
Collection date: 10/24/2020
D 227
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-209
Client Sample Identification Number 169.3-206
Collection date: 10/24/2020
D 226
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-210
Client Sample Identification Number 169.3-207
Collection date: 10/24/2020
D 225
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-211
Client Sample Identification Number 169.3-208
Collection date: 10/24/2020
D 224
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-212
Client Sample Identification Number 169.3-209
Collection date: 10/24/2020
D 222
Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-213
Client Sample Identification Number 169.3-210
Collection date: 10/24/2020
D 221

Micrograms per liter: less than 1.00
Analysis Date: 11/20/2020
Laboratory Sample Number: 20-10-0 6 1 2 8-214
Client Sample Identification Number 169.3-211
Collection date: 10/24/2020
D220

Micrograms per liter: 1.04
Analysis Date: 11/20/2020

Method: SM 3 1 1 3 B – 2 0 1 0
Analyst: Jennalee Hertzler
Accreditation Number: New York 1 1 7 1 4
Reviewed and Authorized Signatory by Melissa Kanode; Quality Assurance Quality Control Clerk

Sample results denoted with a "less than" sign contain less than the reporting limit which is 1 part per billion.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 parts per billion. The results herein conform to National Environmental Laboratory Accreditation Conference standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

1.5 Laboratory Certifications

New York State Department of Health Wadsworth Center

Certificate of Approval for Laboratory Service

issued in accordance with and pursuant to section 502 Public Health Law of New York state

Expires 12:01 AM April 01, 2021

Issued April 01, 2020

New York Laboratory Identification Number: 1 1 7 1 4

Ms. Julie Dickerson

Environmental Hazards Services, L.L.C.

7469 Whitepine Road

North Chesterfield, VA 23237

is hereby approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category Environmental Analyses Potable Water.

All approved analytes are listed below:

Metals 1

Copper, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Lead, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Serial Number: 6 1 5 1 4

Property of the New York State Department of Health. Certificates are valid only at the address shown; must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518)485-5570 to verify the laboratory's accreditation status.

1.6 Chains of Custody

Chain of Custody Document submitted to Environmental Hazards Services, L.L.C.

Stohl Job Number: 2 0 2 0 L -169 .3

Lancaster Central School District

Contact: Michael Bryniarski

William Street School

5201 William Street, Lancaster, New York 14086

Lead: Water by S M 19, 21-23 3 1 1 3 B (-04, -10)

Turnaround 20 days

Sample Number	169.3-1	Loading Dock Left Lavatory	Outlet Type Sink	8:00
Sample Number	169.3-2	Loading Dock Right Lavatory	Outlet Type Sink	8:01
Sample Number	169.3-3	Kitchen Handwash by freezers	Outlet Type Sink	8:02
Sample Number	169.3-4	Kitchen 2 bay	Outlet Type Sink	8:03
Sample Number	169.3-5	Kitchen Single Bay	Outlet Type Sink	8:04
Sample Number	169.3-6	Kitchen Handwash Corner	Outlet Type Sink	8:05
Sample Number	169.3-7	Kitchen Dish Sprayer	Outlet Type sink	8:06
Sample Number	169.3-8	Kitchen Dish Single Bay	Outlet Type Sink	8:07
Sample Number	169.3-9	Kitchen Dish 2 bay	Outlet Type Sink	8:08
Sample Number	169.3-10	Kitchen Kettle	Outlet Type Sink	8:09

Sample Number	169.3-11	Kitchen Single by Coffee	Outlet Type sink	8:10
Sample Number	169.3-12	Dishwasher Left	Outlet Type Sink	8:11
Sample Number	169.3-13	Dishwasher Right	Outlet Type Sink	8:12
Sample Number	169.3-14	Dish Sprayer by Cafeteria	Outlet Type Sink	8:13
Sample Number	169.3-15	Dish Room Handwash	Outlet Type Sink	8:14
Sample Number	169.3-16	Serving Handwash	Outlet Type Sink	8:15
Sample Number	169.3-17	Serving Handwash by Fridges	Outlet Type Sink	8:16
Sample Number	169.3-18	Handwash by Stove	Outlet Type Sink	8:17
Sample Number	169.3-19	Handwash by Office	Outlet Type Sink	8:18
Sample Number	169.3-20	Kitchen Ice Machine	Outlet Type I M	8:19
Sample Number	169.3-21A	Cafeteria	Outlet Type D F A	8:20
Sample Number	169.3-21B	Cafeteria	Outlet Type D F B	8:21
Sample Number	169.3-22	Girls Lavatory B1 Left	Outlet Type Sink	8:22
Sample Number	169.3-23	Girls Lavatory B1 Center	Outlet Type Sink	8:23
Sample Number	169.3-24	Girls Lavatory B1 Right	Outlet Type Sink	8:24
Sample Number	169.3-25	Boys Lavatory B1 Left	Outlet Type Sink	8:25
Sample Number	169.3-26	Boys Lavatory B1 Center	Outlet Type Sink	8:26
Sample Number	169.3-27	Boys Lavatory B1 Right	Outlet Type Sink	8:27
Sample Number	169.3-28A	B 1 Fountain	Outlet Type D F A	8:28
Sample Number	169.3-28B	B 1 Fountain	Outlet Type D F B	8:29
Sample Number	169.3-29	B 109	Outlet Type Sink	8:30
Sample Number	169.3-30	B 108	Outlet Type Sink	8:31
Sample Number	169.3-31	B 107	Outlet Type Sink	8:32
Sample Number	169.3-32A	B Common Fountain	Outlet Type D F A	8:33
Sample Number	169.3-32B	B Common Fountain	Outlet Type D F B	8:34
Sample Number	169.3-33	B 106 Front	Outlet Type Sink	8:35
Sample Number	169.3-34	B 106 Rear	Outlet Type Sink	8:36
Sample Number	169.3-35	B 106 Sprayer	Outlet Type Sink	8:37
Sample Number	169.3-36	Left Lavatory Outside B105	Outlet Type Sink	8:38
Sample Number	169.3-37	B 105 Faculty	Outlet Type Sink	8:39
Sample Number	169.3-38	Right Lavatory Outside B105	Outlet Type Sink	8:40
Sample Number	169.3-39	B 104	Outlet Type Sink	8:41
Sample Number	169.3-40	B 103	Outlet Type Sink	8:42
Sample Number	169.3-41	B 102	Outlet Type Sink	8:43
Sample Number	169.3-42	B 101	Outlet Type Sink	8:44
Sample Number	169.3-43	B 112 Band Lesson	Outlet Type Sink	8:45
Sample Number	169.3-44	B 113 Library Classroom	Outlet Type Sink	8:46
Sample Number	169.3-45	D 117 Main Office Kitchen	Outlet Type Sink	8:47
Sample Number	169.3-46	D 117 Main Office Lavatory	Outlet Type Sink	8:48
Sample Number	169.3-47	C 132 Chorus	Outlet Type Sink	8:49
Sample Number	169.3-48	C 133 Sink	Outlet Type Sink	8:50
Sample Number	169.3-49	C 133 Fountain	Outlet Type Bubbler	8:51
Sample Number	169.3-50	C 1 Women's Faculty Lavatory	Outlet Type Sink	8:52
Sample Number	169.3-51	C 1 Men's Faculty Lavatory	Outlet Type Sink	8:53
Sample Number	169.3-52	C 1 Girls Gang Left	Outlet Type Sink	8:54
Sample Number	169.3-53	C 1 Girls Gang Left Center	Outlet Type Sink	8:55
Sample Number	169.3-54	C 1 Girls Gang Right Center	Outlet Type Sink	8:56
Sample Number	169.3-56	C 1 Boys Gang Left	Outlet Type Sink	8:57
Sample Number	169.3-57	C 1 Boys Gang Left Center	Outlet Type Sink	8:58
Sample Number	169.3-58	C 1 Boys Gang Right Center	Outlet Type Sink	8:59
Sample Number	169.3-59	C 1 Boys Gang Right	Outlet Type Sink	9:00
Sample Number	169.3-60	C 1 Boys Side Fountain Left	Outlet Type Bubbler	9:01
Sample Number	169.3-61	C 1 Boys Side Fountain Right	Outlet Type Sink	9:02

Sample Number	169.3-62	C 1 Girls Side Fountain Left	Outlet Type Bubbler	9:03
Sample Number	169.3-63	C 1 Girls Side Fountain Right	Outlet Type Sink	9:04
Sample Number	169.3-64	C 146	Outlet Type Sink	9:05
Sample Number	169.3-65	C 145	Outlet Type Sink	9:06
Sample Number	169.3-66	C 144	Outlet Type Sink	9:07
Sample Number	169.3-67	C 143	Outlet Type Sink	9:08
Sample Number	169.3-68	C 142	Outlet Type Sink	9:09
Sample Number	169.3-69	C 141	Outlet Type Sink	9:10
Sample Number	169.3-70	C 139	Outlet Type Sink	9:11
Sample Number	169.3-71	C 138	Outlet Type Sink	9:12
Sample Number	169.3-72	C 137	Outlet Type Sink	9:13
Sample Number	169.3-73	C 136	Outlet Type Sink	9:14
Sample Number	169.3-74	C 135	Outlet Type Sink	9:15
Sample Number	169.3-75	C 134	Outlet Type Sink	9:16
Sample Number	169.3-76	D 118 Nurse Main	Outlet Type Sink	9:17
Sample Number	169.3-77	D 118 Nurse Exam	Outlet Type Sink	9:18
Sample Number	169.3-78	D 118 Nurse Lavatory	Outlet Type Sink	9:19
Sample Number	169.3-79	Girls Pool Locker Room Left	Outlet Type Sink	9:20
Sample Number	169.3-80	Girls Pool Locker Room Center	Outlet Type Sink	9:21
Sample Number	169.3-81	Girls Pool Locker Room Right	Outlet Type Sink	9:22
Sample Number	169.3-82	Boys Pool Locker Room Left	Outlet Type Sink	9:23
Sample Number	169.3-83	Boys Pool Locker Room Center	Outlet Type Sink	9:24
Sample Number	169.3-84	Boys Pool Locker Room Right	Outlet Type Sink	9:25
Sample Number	169.3-85	New Gym Girl Side Fountain Left	Outlet Type Sink	9:26
Sample Number	169.3-86	New Gym Girl Side Fountain Right	Outlet Type Sink	9:27
Sample Number	169.3-87	New Gym Boy Side Fountain Left	Outlet Type Sink	9:28
Sample Number	169.3-88	New Gym Boy Side Fountain Right	Outlet Type Sink	9:29
Sample Number	169.3-90	Old Gym Boys Locker Center	Outlet Type Sink	9:30
Sample Number	169.3-91	Old Gym Boys Locker Right	Outlet Type Sink	9:31
Sample Number	169.3-92	Old Gym Boys Coach Office	Outlet Type Sink	9:32
Sample Number	169.3-93	Old Gym Girls Locker Left	Outlet Type Sink	9:33
Sample Number	169.3-94	Old Gym Girls Locker Center	Outlet Type Sink	9:34
Sample Number	169.3-95	Old Gym Girls Locker Right	Outlet Type Sink	9:35
Sample Number	169.3-96	Old Gym Girls Coach Office	Outlet Type Sink	9:36
Sample Number	169.3-97A	Old Gym Girls Side Fountain	Outlet Type D F A	9:37
Sample Number	169.3-97B	Old Gym Girls Side Fountain	Outlet Type D F B	9:38
Sample Number	169.3-98	D Boys Gang Left	Outlet Type Sink	9:39
Sample Number	169.3-99	D Boys Gang Center	Outlet Type Sink	9:40
Sample Number	169.3-100	D Boys Gang Right	Outlet Type Sink	9:41
Sample Number	169.3-101	D Girls Gang left	Outlet Type Sink	9:42
Sample Number	169.3-102	D Girls Gang Center	Outlet Type Sink	9:43
Sample Number	169.3-103	D Girls Gang Right	Outlet Type Sink	9:44
Sample Number	169.3-104A	D Fountain	Outlet Type D F A	9:45
Sample Number	169.3-104B	D Fountain	Outlet Type D F B	9:46
Sample Number	169.3-105	D 122	Outlet Type Sink	9:47
Sample Number	169.3-106	D 123	Outlet Type Sink	9:48
Sample Number	169.3-107	D 124	Outlet Type Sink	9:49
Sample Number	169.3-108A	D Rear Fountain	Outlet Type D F A	9:50
Sample Number	169.3-108B	D Rear Fountain	Outlet Type D F B	9:51
Sample Number	169.3-109	D 125	Outlet Type Sink	9:52
Sample Number	169.3-110	D Men's Faculty Lavatory	Outlet Type Sink	9:53
Sample Number	169.3-111	D 126	Outlet Type Sink	9:54
Sample Number	169.3-112	D Women's Faculty Lavatory	Outlet Type Sink	9:55

Sample Number	169.3-113	D 127	Outlet Type Sink	9:56
Sample Number	169.3-114	D 128	Outlet Type Sink	9:57
Sample Number	169.3-115	D 129	Outlet Type Sink	9:58
Sample Number	169.3-116	D 130	Outlet Type Sink	9:59
Sample Number	169.3-117	B 210	Outlet Type Sink	10:00
Sample Number	169.3-118	B 209	Outlet Type Sink	10:01
Sample Number	169.3-119	B 208	Outlet Type Sink	10:02
Sample Number	169.3-120A	B Rear Fountain	Outlet Type D F A	10:03
Sample Number	169.3-120B	B Rear Fountain	Outlet Type D F B	10:04
Sample Number	169.3-121	B 206 Front	Outlet Type Sink	10:05
Sample Number	169.3-122	B 206 Rear	Outlet Type Sink	10:06
Sample Number	169.3-123	B 206 Sprayer	Outlet Type Sink	10:07
Sample Number	169.3-124	B Women's Faculty Lavatory	Outlet Type Sink	10:08
Sample Number	169.3-125	B 205	Outlet Type Sink	10:09
Sample Number	169.3-126	B Men's Faculty Lavatory	Outlet Type Sink	10:10
Sample Number	169.3-127	B 204 Front	Outlet Type Sink	10:11
Sample Number	169.3-128	B 204 Rear	Outlet Type Sink	10:12
Sample Number	169.3-130	B 203	Outlet Type Sink	10:13
Sample Number	169.3-131	B 202	Outlet Type Sink	10:14
Sample Number	169.3-132	B 201	Outlet Type Sink	10:15
Sample Number	169.3-133	B 2 Fountain	Outlet Type D F A	10:16
Sample Number	169.3-134	B 2 Boys Gang Left	Outlet Type Sink	10:17
Sample Number	169.3-135	B 2 Boys Gang Center	Outlet Type Sink	10:18
Sample Number	169.3-136	B 2 Boys Gang Right	Outlet Type Sink	10:19
Sample Number	169.3-137	8 2 Girls Gang Lavatory Left	Outlet Type Sink	10:20
Sample Number	169.3-139	8 2 Girls Gang Lavatory Right	Outlet Type Sink	10:21
Sample Number	169.3-140	B 200	Outlet Type Sink	10:22
Sample Number	169.3-141	B 211	Outlet Type Sink	10:23
Sample Number	169.3-142	B 213	Outlet Type Sink	10:24
Sample Number	169.3-143	B 214	Outlet Type Sink	10:25
Sample Number	169.3-144	B 2158 Center Front	Outlet Type Sink	10:26
Sample Number	169.3-145	B 215B Center Rear	Outlet Type Sink	10:27
Sample Number	169.3-146	B 215B Corner Handwash	Outlet Type Sink	10:28
Sample Number	169.3-147	B 215A Left Front	Outlet Type Sink	10:29
Sample Number	169.3-148	B 215A Right Rear	Outlet Type Sink	10:30
Sample Number	169.3-149	B 217	Outlet Type Sink	10:31
Sample Number	169.3-150	B 218	Outlet Type Sink	10:32
Sample Number	169.3-151	C2 Girls Side Fountain Left	Outlet Type Bubbler	10:33
Sample Number	169.3-152	C2 Girls Side Fountain Right	Outlet Type Bubbler	10:34
Sample Number	169.3-153	C 253	Outlet Type Sink	10:35
Sample Number	169.3-154	C 252	Outlet Type Sink	10:36
Sample Number	169.3-155	C 251	Outlet Type Sink	10:37
Sample Number	169.3-156	C 250	Outlet Type Sink	10:38
Sample Number	169.3-157	C 249	Outlet Type Sink	10:39
Sample Number	169.3-158	C 248	Outlet Type Sink	10:40
Sample Number	169.3-159	C 246	Outlet Type Sink	10:41
Sample Number	169.3-160	C 245	Outlet Type Sink	10:42
Sample Number	169.3-161	C 244	Outlet Type Sink	10:43
Sample Number	169.3-162	C 243	Outlet Type Sink	10:44
Sample Number	169.3-163	C 242	Outlet Type Sink	10:45
Sample Number	169.3-164	C 241	Outlet Type Sink	10:46
Sample Number	169.3-165	C2 Boys Side Fountain Left	Outlet Type Bubbler	10:47
Sample Number	169.3-166	C2 Boys Side Fountain Right	Outlet Type Bubbler	10:48

Sample Number	169.3-167	C2 Boys Lavatory Left	Outlet Type Sink	10:49
Sample Number	169.3-168	C2 Boys Lavatory Left Center	Outlet Type Sink	10:50
Sample Number	169.3-169	C2 Boys Lavatory Right Center	Outlet Type Sink	10:51
Sample Number	169.3-170	C2 Boys Lavatory Right	Outlet Type Sink	10:52
Sample Number	169.3-171	C2 Girls Lavatory Left	Outlet Type Sink	10:53
Sample Number	169.3-172	C2 Girls Lavatory Left Center	Outlet Type Sink	10:54
Sample Number	169.3-173	C2 Girls Lavatory Right Center	Outlet Type Sink	10:55
Sample Number	169.3-174	C2 Girls Lavatory Right	Outlet Type Sink	10:56
Sample Number	169.3-175	C2 Men's Faculty Lavatory	Outlet Type Sink	10:57
Sample Number	169.3-176	C2 Women's Faculty Lavatory	Outlet Type Sink	10:58
Sample Number	169.3-177	C 240 Front Middle	Outlet Type Sink	10:59
Sample Number	169.3-178	C 240 Back Middle	Outlet Type Sink	11:00
Sample Number	169.3-179	C 239	Outlet Type Sink	11:01
Sample Number	169.3-180	C 219	Outlet Type Sink	11:02
Sample Number	169.3-181	D 228	Outlet Type Sink	11:03
Sample Number	169.3-182	D 229	Outlet Type Sink	11:04
Sample Number	169.3-183	D 230	Outlet Type Sink	11:05
Sample Number	169.3-184A	D Rear Fountain	Outlet Type D F A	11:06
Sample Number	169.3-184B	D Rear Fountain	Outlet Type D F B	11:07
Sample Number	169.3-185	D 232 Front	Outlet Type Sink	11:08
Sample Number	169.3-186	D 232 Rear	Outlet Type Sink	11:09
Sample Number	169.3-187	D 232 Sprayer	Outlet Type Sink	11:10
Sample Number	169.3-188	D Men's Faculty Lavatory	Outlet Type Sink	11:11
Sample Number	169.3-189	D 233	Outlet Type Sink	11:12
Sample Number	169.3-190	D Women's Faculty Lavatory	Outlet Type Sink	11:13
Sample Number	169.3-191	D 234 Front	Outlet Type Sink	11:14
Sample Number	169.3-192	D 234 Rear	Outlet Type Sink	11:15
Sample Number	169.3-194	D 235	Outlet Type Sink	11:16
Sample Number	169.3-195	D 236	Outlet Type Sink	11:17
Sample Number	169.3-196	D 237	Outlet Type Sin	11:18
Sample Number	169.3-197A	D2 Fountain	Outlet Type D F A	11:19
Sample Number	169.3-197B	D2 Fountain	Outlet Type D F B	11:20
Sample Number	169.3-198	D2 Boys Gang Left	Outlet Type Sink	11:21
Sample Number	169.3-199	D2 Boys Gang Center	Outlet Type Sink	11:22
Sample Number	169.3-200	D2 Boys Gang Right	Outlet Type Sink	11:23
Sample Number	169.3-201	D2 Girls Gang Left	Outlet Type sink	11:24
Sample Number	169.3-202	D2 Girls Gang Center	Outlet Type Sink	11:25
Sample Number	169.3-203	D2 Girls Gang Right	Outlet Type Sink	11:26
Sample Number	169.3-204	D 238	Outlet Type Sink	11:27
Sample Number	169.3-205	D 227	Outlet Type Sink	11:28
Sample Number	169.3-206	D 226	Outlet Type Sink	11:29
Sample Number	169.3-207	D 225	Outlet Type Sink	11:30
Sample Number	169.3-208	D 224	Outlet Type Sink	11:31
Sample Number	169.3-209	D 222	Outlet Type Sink	11:32
Sample Number	169.3-210	D 221	Outlet Type Sink	11:33
Sample Number	169.3-211	D 220	Outlet Type Sink	11:34

Sample 169.3-150 was received empty – signature 10/30/2020

Please e-mail lab results to labs@stohlenv.com If checked, also e-mail results to:
Ehenderson@StohlEnv.com

Sampled By: C. Schultz and P. Nichols Stohl Environmental 10/24/2020

Relinquished By: Eric Henderson Jr. 10/26/2020

Received (Name, Laboratory): T. Stone 10/29/20 at 6:27pm

Sample Login (Name, Laboratory): Traci Bloom 11/18/2020 at 7:34am

Analysis (Name, Laboratory): J. Hertzler 11/23/2020 at 8:42am

Archived, Released: signature 11/24/2020 at 1:00pm