

Water Sampling – Lancaster Middle School Final Report

Stohl Environmental  
3860 California Road Orchard Park, New York 14127  
Phone: 716-312-0070 Fax: 716-312-8092  
www.stohlenvironmental.com

December 15, 2020

Mr. Michael Bryniarski  
Director of Facilities  
Lancaster Central School District  
177 Central Avenue  
Lancaster, NY 14086

Regarding: Investigation and Sampling of Drinking Water for Lead Concentrations

Dear Mr. Bryniarski:

Included with this letter is Stohl Environmental LLC's report for the Water Sampling performed at the educational buildings of the Lancaster Central School District, including:  
Lancaster Middle School – 148 Aurora Street, Lancaster, New York.

This report is prepared to assist the District in complying with the requirements of New York State regulations, Subpart 67-4: Lead Testing in School Drinking Water, by identifying the sources of potable water with lead concentrations greater than the New York State "Action Level of 15 parts per billion (p.p.b)".

The Investigation and Sampling was performed on October 17, 2020. The Protocol for the Investigation followed the requirements of New York State regulations as well as United States Environmental Protection Agency Technical Guidance "3 T's for Reducing Lead in Drinking Water in Schools".

As detailed in Section 1.2 (Executive Summary) of the accompanying report, based upon the sampling and analysis performed, 10 sources of potable water in the Middle School have been identified as having lead concentration in water above the New York State Action Level of 15 parts per billion. To comply with New York State regulations, Response actions as identified in this report by the District are required.

Thank you for the opportunity to be of service to Lancaster Central School District.

"Signature of Eric Henderson Jr."  
Senior Project Manager

Investigation and Sampling of Sources of Potable Water for Lead Concentrations Prepared for: Lancaster Central School District Prepared by:

Stohl Environmental  
3860 California Road  
Orchard Park, New York 14127  
Phone (716) 312-0070 Fax (716) 312-8092  
www.stohlenvironmental.com

Conditions as of October 17, 2020

Summary Tabulation Lead in Drinking Water Investigation

- 1.1. Scope of Work and Sampling Protocol
- 1.2. Executive Summary of Sampling and Analysis
- 1.3. Response Actions Required Under New York State
- 1.4. Regulations Laboratory Analytical Reports by
- 1.5. Building Laboratory Certifications
- 1.6. Chains of Custody

1.1 Scope of Work and Sampling Protocol:

Stohl Environmental was retained by Lancaster Central School District to perform sampling and analysis of potable water for elevated lead concentrations. Sampling was performed in the following buildings:

Lancaster Middle School – 148 Aurora Street, Lancaster, New York.

Scope of Work:

Stohl Environmental was charged with collecting first-draw water samples from outlets within the Transportation Department. Outlets are defined in New York State regulations as: "a potable water fixture currently or potentially used for drinking or cooking purposes, including but not limited to a bubbler, drinking fountain, or faucets".

Sampling Protocol:

In accordance with New York State regulations, Subpart 67 -4: Lead Testing in School Drinking Water, and the Environmental Protection Agency guidance document, "3Ts for Reducing Lead in Drinking Water in Schools", Stohl Environmental's protocol can be summarized as follows:

First-draw samples of 250 milliliters (mL) were collected from cold water outlets before any water was used. Sampling was coordinated with District representatives to assure that water was motionless in the pipes for a minimum of 8 hours, but not more than 18 hours before sample collection.

Laboratory Analysis: Samples were submitted following strict chain-of-custody protocols to an independent laboratory approved by the New York State Department of Health's Environmental Laboratory Approval Program (E L A P).

## 1.2 Executive Summary of Sampling and Analysis:

Total Number of Samples Collected by Building Classified by First Draw and Confirmatory Samples:

The date of sample event on 10/17/2020 the Middle School had a total of 123 samples collected. The First draw samples had 113 samples at or below action level of 15 parts per billion and 10 samples above action level of 15 parts per billion.

The date of sample event on 10/17/2020 the Middle School had confirmatory samples at or below action level of 15 parts per billion and above action level of 15 parts per billion that are not applicable. Confirmatory samples are samples collected subsequent to "Step 1" First Draw samples to verify initial findings of lead contamination, to assist in problem assessment to determine remediation and/or verify that lead levels are at or below action level post-remediation.

### Listings of Outlet Requiring Remediation

Locations of Outlets analyzed above New York State level of 15 parts per billion based upon analysis of first draw samples:

Sample Number 1692-31	Room 217 Vestibule	Fixture	Sink	Laboratory Analysis parts per billion	36.6
Sample Number 169.2-32	Room 218	Fixture	Sink	Laboratory Analysis parts per billion	62.6
Sample Number 169.2-34	Art Room 112 Far Left	Fixture	Sink	Laboratory Analysis parts per billion	40.4
Sample Number 169.2-35	Art Room 112 Far Center	Fixture	Sink	Laboratory Analysis parts per billion	18.8
Sample Number 169.2-36	Art Room 112 Far Right	Fixture	Sink	Laboratory Analysis parts per billion	32.5
Sample Number 169.2-37	Art Room 112 Closet Left	Fixture	Sink	Laboratory Analysis parts per billion	61.2
Sample Number 169.2-38	Art Room 112 Close Center	Fixture	Sink	Laboratory Analysis parts per billion	20.9
Sample Number 169.2-39	Art Room 112 Close Right	Fixture	Sink	Laboratory Analysis parts per billion	15.7
Sample Number 169.2-52	Room 108	Fixture	Sink	Laboratory Analysis parts per billion	33.5
Sample Number 169.2-98	Room 120	Fixture	Sink	Laboratory Analysis parts per billion	15.4

## 1.3 Response Actions Required Under New York State Regulations, Section 67-4.4:

For outlets analyzed with a lead concentration in excess of the New York State Action Level, regulations require:

- (a) Prohibit use of the outlet until:
  - (1) a lead remediation plan is implemented to mitigate the lead level of such outlet; and
  - (2) test results indicate that the lead levels are at or below the action level;
- (b) Provide building occupants with an adequate supply of potable water for drinking and cooking until remediation is performed;
- (c) Report the test results to the local health department as soon as practicable, but no more than 1 business day after the school received the laboratory report; and
- (d) Notify all staff and all persons in parental relation to students of the test results, in writing, as soon as practicable but no more than 10 business days after the school received the laboratory report.

## 1.4 Laboratory Analytical Reports by Building

Environmental Hazards Services, LLC  
7469 Whitepine Road  
Richmond, VA 23237  
Telephone: 800-347-4010

Lead in Drinking Water Analysis Report

Report Number: 20 - 10 - 0 4 9 1 4

Client: Stohl Environmental 3860 California Road Orchard Park, NY 14127

Received Date: 10/22/2020

Reported Date: 11/13/2020

Sampled By: Christine Schultz

Tech Certification Number:

Project Test Address: 2 0 2 0 L-169 .2; Lancaster Middle School; 148 Aurora Street.; Lancaster, NY 14086

Client Number: 33 - 5 9 8 0

Fax Number: 716-312-8092

Laboratory Results

Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 1

Client Sample Identification Number 169.2-1

Collection date: 10/17/2020

Third Floor Boy's Lavatory

Micrograms per liter: 2.68

Analysis Date: 11/10/2020

Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 2

Client Sample Identification Number 169.2-2A

Collection date: 10/17/2020

304 Hallway

Micrograms per liter: 1.94

Analysis Date: 11/10/2020

Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 3

Client Sample Identification Number 169.2-2B

Collection date: 10/17/2020

304 Hallway

Micrograms per liter: less than 1.00

Analysis Date: 11/10/2020

Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 4

Client Sample Identification Number 169.2-3A

Collection date: 10/17/2020

306 Hallway

Micrograms per liter: less than 1.00

Analysis Date: 11/10/2020

Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 5

Client Sample Identification Number 169.2-3B

Collection date: 10/17/2020

306 Hallway

Micrograms per liter: less than 1.00

Analysis Date: 11/10/2020

Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 6

Client Sample Identification Number 169.2-4

Collection date: 10/17/2020

Third Floor Girl's Lavatory

Micrograms per liter: less than 1.00

Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 7  
Client Sample Identification Number 169.2-5  
Collection date: 10/17/2020  
200 Hallway Girl's Lavatory Left  
Micrograms per liter: 3.06  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 8  
Client Sample Identification Number 169.2-6  
Collection date: 10/17/2020  
200 Hallway Girl's Lavatory Center  
Micrograms per liter: 4.73  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 0 9  
Client Sample Identification Number 169.2-7  
Collection date: 10/17/2020  
200 Hallway Girl's Lavatory Right  
Micrograms per liter: 1.96  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 10  
Client Sample Identification Number 169.2-8A  
Collection date: 10/17/2020  
200 Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 11  
Client Sample Identification Number 169.2-8B  
Collection date: 10/17/2020  
200 Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 12  
Client Sample Identification Number 169.2-9  
Collection date: 10/17/2020  
200 Hallway Boy's Lavatory Left  
Micrograms per liter: 3.38  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 13  
Client Sample Identification Number 169.2-10  
Collection date: 10/17/2020  
200 Hallway Boy's Lavatory Center  
Micrograms per liter: 2.21  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 14  
Client Sample Identification Number 169.2-11  
Collection date: 10/17/2020  
200 Hallway Boy's Lavatory Right  
Micrograms per liter: 2.39

Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 15  
Client Sample Identification Number 169.2-12  
Collection date: 10/17/2020  
206 204 Middle Office Right  
Micrograms per liter: 8.72  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 16  
Client Sample Identification Number 169.2-13  
Collection date: 10/17/2020  
206 204 Middle Office Left  
Micrograms per liter: 7.73  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 17  
Client Sample Identification Number 169.2-14A  
Collection date: 10/17/2020  
206 Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 18  
Client Sample Identification Number 169.2-14B  
Collection date: 10/17/2020  
206 Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 19  
Client Sample Identification Number 169.2-15  
Collection date: 10/17/2020  
Art Room 209 Left  
Micrograms per liter: 12.1  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 20  
Client Sample Identification Number 169.2-16  
Collection date: 10/17/2020  
Art Room 209 Right  
Micrograms per liter: 14.1  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 21  
Client Sample Identification Number 169.2-17  
Collection date: 10/17/2020  
214 Hallway Boy's Lavatory Left  
Micrograms per liter: 2.20  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 22  
Client Sample Identification Number 169.2-18A  
Collection date: 10/17/2020  
214 Hallway  
Micrograms per liter: less than 1.00

Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 23  
Client Sample Identification Number 169.2-18B  
Collection date: 10/17/2020  
214 Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 24  
Client Sample Identification Number 169.2-19A  
Collection date: 10/17/2020  
Library Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 25  
Client Sample Identification Number 169.2-19B  
Collection date: 10/17/2020  
Library Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 26  
Client Sample Identification Number 169.2-20  
Collection date: 10/17/2020  
Library Kitchenette  
Micrograms per liter: 2.91  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 27  
Client Sample Identification Number 169.2-21  
Collection date: 10/17/2020  
Library Hallway Girl's Lavatory  
Micrograms per liter: 1.82  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 28  
Client Sample Identification Number 169.2-22  
Collection date: 10/17/2020  
Second Floor Faculty Lavatory  
Micrograms per liter: 1.70  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 29  
Client Sample Identification Number 169.2-23  
Collection date: 10/17/2020  
Second Floor Lounge Water Cooler  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 30  
Client Sample Identification Number 169.2-24  
Collection date: 10/17/2020  
Second Floor Lounge Lavatory  
Micrograms per liter: 1.61

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 31  
Client Sample Identification Number 169.2-25  
Collection date: 10/17/2020  
Room 216 East  
Micrograms per liter: 9.98  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 32  
Client Sample Identification Number 169.2-26  
Collection date: 10/17/2020  
Room 216 South  
Micrograms per liter: 6.79  
Analysis Date: 11/06/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 33  
Client Sample Identification Number 169.2-27  
Collection date: 10/17/2020  
Room 216 West  
Micrograms per liter: 2.52  
Analysis Date: 11/10/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 34  
Client Sample Identification Number 169.2-28  
Collection date: 10/17/2020  
Room 216 North  
Micrograms per liter: 3.40  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 25  
Client Sample Identification Number 169.2-29  
Collection date: 10/17/2020  
Room 217 North  
Micrograms per liter: 11.6  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 36  
Client Sample Identification Number 169.2-30  
Collection date: 10/17/2020  
Room 217 East  
Micrograms per liter: 9.45  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 37  
Client Sample Identification Number 169.2-31  
Collection date: 10/17/2020  
Room 217 West  
Micrograms per liter: 36.6  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 38  
Client Sample Identification Number 169.2-32  
Collection date: 10/17/2020  
Room 218  
Micrograms per liter: 62.6



Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 39  
Client Sample Identification Number 169.2-33  
Collection date: 10/17/2020  
Room 111  
Micrograms per liter: 3.45  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 40  
Client Sample Identification Number 169.2-34  
Collection date: 10/17/2020  
Art Room 1120 Far Left  
Micrograms per liter: 40.4  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 41  
Client Sample Identification Number 169.2-35  
Collection date: 10/17/2020  
Art Room 112 Far Center  
Micrograms per liter: 18.8  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 42  
Client Sample Identification Number 169.2-36  
Collection date: 10/17/2020  
Art Room 112 Far Left  
Micrograms per liter: 32.5  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 43  
Client Sample Identification Number 169.2-37  
Collection date: 10/17/2020  
Art Room 112 Close Left  
Micrograms per liter: 61.2  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 44  
Client Sample Identification Number 169.2-38  
Collection date: 10/17/2020  
Art Room 112 Close Center  
Micrograms per liter: 20.9  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 45  
Client Sample Identification Number 169.2-39  
Collection date: 10/17/2020  
Art Room 112 Close Right  
Micrograms per liter: 15.7  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 46  
Client Sample Identification Number 169.2-40  
Collection date: 10/17/2020  
Faculty Room by 113 Lavatory  
Micrograms per liter: 5.59

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 47  
Client Sample Identification Number 169.2-41  
Collection date: 10/17/2020  
Music Room 113  
Micrograms per liter: 1.14  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 48  
Client Sample Identification Number 169.2-42  
Collection date: 10/17/2020  
Auditorium Girl's Lavatory Left  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 49  
Client Sample Identification Number 169.2-43  
Collection date: 10/17/2020  
Auditorium Girl's Lavatory Right  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 50  
Client Sample Identification Number 169.2-44  
Collection date: 10/17/2020  
Counseling Center  
Micrograms per liter: 1.25  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 51  
Client Sample Identification Number 169.2-45  
Collection date: 10/17/2020  
Administrative Office Kitchenette  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 52  
Client Sample Identification Number 169.2-46  
Collection date: 10/17/2020  
Administrative Office Lavatory  
Micrograms per liter: 1.79  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 53  
Client Sample Identification Number 169.2-47  
Collection date: 10/17/2020  
Auditorium Boy's Lavatory Left  
Micrograms per liter: 1.21  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 54  
Client Sample Identification Number 169.2-48  
Collection date: 10/17/2020  
Auditorium Boy's Lavatory Right  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 55  
Client Sample Identification Number 169.2-49  
Collection date: 10/17/2020  
Copy Room Lavatory  
Micrograms per liter: 1.72  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 56  
Client Sample Identification Number 169.2-51  
Collection date: 10/17/2020  
Room 108A  
Micrograms per liter: 10.5  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 57  
Client Sample Identification Number 169.2-52  
Collection date: 10/17/2020  
Room 108  
Micrograms per liter: 33.5  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 58  
Client Sample Identification Number 169.2-53  
Collection date: 10/17/2020  
Nurse Ice Machine  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 59  
Client Sample Identification Number 169.2-54  
Collection date: 10/17/2020  
Nurse Back Lavatory  
Micrograms per liter: 7.17  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 60  
Client Sample Identification Number 169.2-55  
Collection date: 10/17/2020  
Nurse Main Handwash  
Micrograms per liter: 7.14  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 61  
Client Sample Identification Number 169.2-56  
Collection date: 10/17/2020  
Nurse Front Lavatory  
Micrograms per liter: 1.24  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 62  
Client Sample Identification Number 169.2-57A  
Collection date: 10/17/2020  
106 Hallway  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 63  
Client Sample Identification Number 169.2-57B  
Collection date: 10/17/2020  
106 Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 64  
Client Sample Identification Number 169.2-58  
Collection date: 10/17/2020  
104 106 Middle Office Left  
Micrograms per liter: 2.67  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 65  
Client Sample Identification Number 169.2-59  
Collection date: 10/17/2020  
104 106 Middle Office Right  
Micrograms per liter: 3.42  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 66  
Client Sample Identification Number 169.2-60  
Collection date: 10/17/2020  
100 Hallway Men's Lavatory Left  
Micrograms per liter: 2.77  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 67  
Client Sample Identification Number 169.2-61  
Collection date: 10/17/2020  
100 Hallway Men's Lavatory Center  
Micrograms per liter: 2.83  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 68  
Client Sample Identification Number 169.2-62  
Collection date: 10/17/2020  
100 Hallway Men's Lavatory Right  
Micrograms per liter: 2.09  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 69  
Client Sample Identification Number 169.2-63A  
Collection date: 10/17/2020  
100 Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 70  
Client Sample Identification Number 169.2-63B  
Collection date: 10/17/2020  
100 Hallway  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 71  
Client Sample Identification Number 169.2-64  
Collection date: 10/17/2020  
100 Hallway Girl's Lavatory Left  
Micrograms per liter: 4.19  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 72  
Client Sample Identification Number 169.2-65  
Collection date: 10/17/2020  
100 Hallway Girl's Lavatory Center  
Micrograms per liter: 2.78  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 73  
Client Sample Identification Number 169.2-66  
Collection date: 10/17/2020  
100 Hallway Girl's Lavatory Right  
Micrograms per liter: 4.76  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 74  
Client Sample Identification Number 169.2-67  
Collection date: 10/17/2020  
Shop Room 164  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 75  
Client Sample Identification Number 169.2-68  
Collection date: 10/17/2020  
Girl's Locker Room Hallway Left  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 76  
Client Sample Identification Number 169.2-69  
Collection date: 10/17/2020  
Girl's Locker Room Hallway Right  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 77  
Client Sample Identification Number 169.2-70  
Collection date: 10/17/2020  
Girls' Team Room  
Micrograms per liter: 12.6  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 78  
Client Sample Identification Number 169.2-71  
Collection date: 10/17/2020  
Girl's Gym Locker Vestibule Left  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 79  
Client Sample Identification Number 169.2-72  
Collection date: 10/17/2020  
Girl's Gym Locker Vestibule Right  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 80  
Client Sample Identification Number 169.2-73  
Collection date: 10/17/2020  
Girl's Gym Locker Lavatory Left  
Micrograms per liter: 3.12  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 81  
Client Sample Identification Number 169.2-74  
Collection date: 10/17/2020  
Girl's Gym Locker Lavatory Left Center  
Micrograms per liter: 2.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 82  
Client Sample Identification Number 169.2-75  
Collection date: 10/17/2020  
Girl's Gym Locker Lavatory Right Center  
Micrograms per liter: 2.13  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 83  
Client Sample Identification Number 169.2-76  
Collection date: 10/17/2020  
Girl's Gym Locker Lavatory Right  
Micrograms per liter: 2.07  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 84  
Client Sample Identification Number 169.2-77  
Collection date: 10/17/2020  
Girl's Gym Coach Office Lavatory  
Micrograms per liter: 4.19  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 85  
Client Sample Identification Number 169.2-78  
Collection date: 10/17/2020  
Girl's Lavatory by 159 Left  
Micrograms per liter: 2.03  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 86  
Client Sample Identification Number 169.2-79  
Collection date: 10/17/2020  
Girl's Lavatory by 159 Left Center  
Micrograms per liter: 2.03

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 87  
Client Sample Identification Number 169.2-80  
Collection date: 10/17/2020  
Girl's Lavatory by 159 Right Center  
Micrograms per liter: 2.64  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 88  
Client Sample Identification Number 169.2-81  
Collection date: 10/17/2020  
Girl's Lavatory by 159 Right  
Micrograms per liter: 2.68  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 89  
Client Sample Identification Number 169.2-82  
Collection date: 10/17/2020  
Faculty Work Room 159  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 90  
Client Sample Identification Number 169.2-83  
Collection date: 10/17/2020  
Faculty Work Room 155  
Micrograms per liter: 1.84  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 91  
Client Sample Identification Number 169.2-84  
Collection date: 10/17/2020  
Boy's Lavatory by 155 Left  
Micrograms per liter: 1.21  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 92  
Client Sample Identification Number 169.2-85  
Collection date: 10/17/2020  
Boy's Lavatory by 155 Left Center  
Micrograms per liter: 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 93  
Client Sample Identification Number 169.2-86  
Collection date: 10/17/2020  
Boy's Lavatory by 155 Right Center  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 94  
Client Sample Identification Number 169.2-88  
Collection date: 10/17/2020  
Boys' Team Room  
Micrograms per liter: 6.25

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 95  
Client Sample Identification Number 169.2-89  
Collection date: 10/17/2020  
Boy's Locker Room Hallway Left  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 96  
Client Sample Identification Number 169.2-90  
Collection date: 10/17/2020  
Boy's Locker Room Hallway Right  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 97  
Client Sample Identification Number 169.2-91  
Collection date: 10/17/2020  
Boy's Coach Office Lavatory  
Micrograms per liter: 1.71  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 98  
Client Sample Identification Number 169.2-92  
Collection date: 10/17/2020  
Boy's Gym Locker Vestibule  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 99  
Client Sample Identification Number 169.2-93  
Collection date: 10/17/2020  
Boy's Gym Locker Lavatory Left  
Micrograms per liter: 2.72  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 100  
Client Sample Identification Number 169.2-94  
Collection date: 10/17/2020  
Boy's Gym Locker Lavatory Left Center  
Micrograms per liter: 2.85  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 101  
Client Sample Identification Number 169.2-95  
Collection date: 10/17/2020  
Boy's Gym Locker Lavatory Right Center  
Micrograms per liter: 1.97  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 102  
Client Sample Identification Number 169.2-96  
Collection date: 10/17/2020  
Boy's Gym Locker Lavatory Right  
Micrograms per liter: 1.92



Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 103  
Client Sample Identification Number 169.2-97A  
Collection date: 10/17/2020  
Cafeteria Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 104  
Client Sample Identification Number 169.2-97B  
Collection date: 10/17/2020  
Cafeteria Hallway  
Micrograms per liter: less than 1.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 105  
Client Sample Identification Number 169.2-98  
Collection date: 10/17/2020  
Room 120  
Micrograms per liter: 15.4  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 106  
Client Sample Identification Number 169.2-100  
Collection date: 10/17/2020  
Kitchen Lavatory  
Micrograms per liter: 2.23  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 107  
Client Sample Identification Number 169.2-101  
Collection date: 10/17/2020  
Kitchen Kettle Sprayer  
Micrograms per liter: 3.58  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 108  
Client Sample Identification Number 169.2-102  
Collection date: 10/17/2020  
Kitchen Single Bay by Kettle  
Micrograms per liter: 1.31  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 109  
Client Sample Identification Number 169.2-103  
Collection date: 10/17/2020  
Kitchen Dish Sprayer South Wall Left  
Micrograms per liter: 3.04  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 110  
Client Sample Identification Number 169.2-104  
Collection date: 10/17/2020  
Kitchen Dish Sprayer South Wall Right  
Micrograms per liter: 8.66

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 111  
Client Sample Identification Number 169.2-105  
Collection date: 10/17/2020  
Kitchen Dish Sprayer by 3 Bay  
Micrograms per liter: 5.82  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 112  
Client Sample Identification Number 169.2-106  
Collection date: 10/17/2020  
Kitchen Faucet Next to 3 Bay  
Micrograms per liter: 4.83  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 113  
Client Sample Identification Number 169.2-107  
Collection date: 10/17/2020  
Kitchen 3 Bay Left  
Micrograms per liter: 6.00  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 114  
Client Sample Identification Number 169.2-108  
Collection date: 10/17/2020  
Kitchen 3 Bay Right  
Micrograms per liter: 3.71  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 115  
Client Sample Identification Number 169.2-109  
Collection date: 10/17/2020  
Kitchen Handwash by Dish Room  
Micrograms per liter: 3.14  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 116  
Client Sample Identification Number 169.2-110  
Collection date: 10/17/2020  
Kitchen Sprayer Next to 2 Bay  
Micrograms per liter: 13.2  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 117  
Client Sample Identification Number 169.2-11  
Collection date: 10/17/2020  
Kitchen 2 Bay  
Micrograms per liter: 3.09  
Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 118  
Client Sample Identification Number 169.2-112  
Collection date: 10/17/2020  
Kitchen Handwash by Serving  
Micrograms per liter: 1.28

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 119  
Client Sample Identification Number 169.2-113A  
Collection date: 10/17/2020  
Cafeteria Fountain  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 120  
Client Sample Identification Number 169.2-113B  
Collection date: 10/17/2020  
Cafeteria Fountain  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 121  
Client Sample Identification Number 169.2-114A  
Collection date: 10/17/2020  
116 Hallway  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 122  
Client Sample Identification Number 169.2-114B  
Collection date: 10/17/2020  
116 Hallway  
Micrograms per liter: less than 1.00

Analysis Date: 11/11/2020  
Laboratory Sample Number: 20-10-0 4 9 1 4-0 123  
Client Sample Identification Number 169.2-115  
Collection date: 10/17/2020  
116 Hallway Lavatory  
Micrograms per liter: 1.83

Analysis Date: 11/11/2020

Method: SM 3 1 1 3 B – 2 0 1 0

Analyst: Jennalee Hertzler

Accreditation Number: New York 1 1 7 1 4

Reviewed and Authorized Signatory by Melissa Kanode; Quality Assurance Quality Control Clerk

Sample results denoted with a "less than" sign contain less than the reporting limit which is 1 part per billion.

The EPA Maximum Contaminant Level for Lead in Drinking Water is 15 parts per billion. The results herein conform to National Environmental Laboratory Accreditation Conference standards, where applicable, unless otherwise narrated on this report. Results represent the analysis of samples submitted by the client. Sample location, description, field parameter results, were provided by the client. This report cannot be reproduced, except in full, without written approval from Environmental Hazards Services, L.L.C.

## 1.5 Laboratory Certifications

New York State Department of Health Wadsworth Center

Certificate of Approval for Laboratory Service

issued in accordance with and pursuant to section 502 Public Health Law of New York state

Expires 12:01 AM April 01, 2021

Issued April 01, 2020

New York Laboratory Identification Number: 1 1 7 1 4

Ms. Julie Dickerson

Environmental Hazards Services, L.L.C.

7469 Whitepine Road

North Chesterfield, VA 23237

is hereby approved as an Environmental Laboratory in conformance with the National Environmental Laboratory Accreditation Conference Standards (2003) for the category Environmental Analyses Potable Water.

All approved analytes are listed below:

Metals 1

Copper, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Lead, Total S M 19, 21-23 3 1 1 3 B (-04, -10)

Serial Number: 6 1 5 1 4

Property of the New York State Department of Health. Certificates are valid only at the address shown; must be conspicuously posted, and are printed on secure paper. Continued accreditation depends on successful ongoing participation in the Program. Consumers are urged to call (518)485-5570 to verify the laboratory's accreditation status.

## 1.6 Chains of Custody

Chain of Custody Document submitted to Environmental Hazards Services, L.L.C.

Stohl Job Number: 2 0 2 0 L -169 .2

Lancaster Central School District

Contact: Michael Bryniarski

Lancaster Middle School

148 Aurora Street, Lancaster, New York 14086

Lead: Water by S M 19, 21-23 3 1 1 3 B (-04, -10)

Turnaround 20 days

Sample Number 169 .2-1	Third Floor Boy's Lavatory	Outlet Type Sink	Time 12:15
Sample Number 169 .2-2A	304 Hallway	Outlet Type D F	Time 12:16
Sample Number 169 .2-2B	304 Hallway	Outlet Type D F B	Time 12:17
Sample Number 169 .2-3A	306 Hallway	Outlet Type D F	Time 12:18
Sample Number 169 .2-3B	306 Hallway	Outlet Type D F B	Time 12:19
Sample Number 169 .2-4	Third Floor Girl's Lavatory	Outlet Type Sink	Time 12:20
Sample Number 169 .2-5	200 Hallway Girl's Lavatory Left	Outlet Type Sink	Time 12:21
Sample Number 169 .2-6	200 Hallway Girl's Lavatory Center	Outlet Type Sink	Time 12:22
Sample Number 169 .2-7	200 Hallway Girl's Lavatory Right	Outlet Type Sink	Time 12:23

Sample Number 169.2-8A	200 Hallway	Outlet Type D F	Time 12:24
Sample Number 169.2-8B	200 Hallway	Outlet Type D F B	Time 12:25
Sample Number 169.2-9	200 Hallway Boy's lavatory Left	Outlet Type Sink	Time 12:26
Sample Number 169.2-10	200 Hallway Boy's Lavatory Center	Outlet Type Sink	Time 12:27
Sample Number 169.2-11	200 Hallway Boy's Lavatory Right	Outlet Type Sink	Time 12:28
Sample Number 169.2-12	206 204 Middle Office Right	Outlet Type Sink	Time 12:29
Sample Number 169.2-13	206 204 Middle Office Left	Outlet Type Sink	Time 12:30
Sample Number 169.2-14A	206 Hallway	Outlet Type D F	Time 12:31
Sample Number 169.2-14B	206 Hallway	Outlet Type D F B	Time 12:32
Sample Number 169.2-15	Art Room 209 Left	Outlet Type Sink	Time 12:33
Sample Number 169.2-16	Art room 209 Right	Outlet Type Sink	Time 12:34
Sample Number 169.2-17	214 Hallway Boy's Lavatory Left	Outlet Type Sink	Time 12:35
Sample Number 169.2-18A	214 Hallway	Outlet Type D F	Time 12:36
Sample Number 169.2-18B	214 Hallway	Outlet Type D F B	Time 12:37
Sample Number 169.2-19A	Library Hallway	Outlet Type D F	Time 12:38
Sample Number 169.2-19B	Library Hallway	Outlet Type D F B	Time 12:39
Sample Number 169.2-20	Library Kitchenette	Outlet Type Sink	Time 12:40
Sample Number 169.2-21	Library Hallway Girl's Lavatory	Outlet Type Sink	Time 12:41
Sample Number 169.2-22	Second Floor Faculty Lavatory	Outlet Type Sink	Time 12:42
Sample Number 169.2-23	Second Floor Lounge Water Cooler	Outlet Type Water Cooler	Time 12:43
Sample Number 169.2-24	Second Floor Lounge Lavatory	Outlet Type Sink	Time 12:44
Sample Number 169.2-25	Room 216 East	Outlet Type Sink	Time 12:45
Sample Number 169.2-26	Room 216 South	Outlet Type Sink	Time 12:46
Sample Number 169.2-27	Room 216 West	Outlet Type Sink	Time 12:47
Sample Number 169.2-28	Room 216 North	Outlet Type Sink	Time 12:48
Sample Number 169.2-29	Room 217 North	Outlet Type Sink	Time 12:49
Sample Number 169.2-30	Room 217 East	Outlet Type Sink	Time 12:50
Sample Number 169.2-31	Room 217 West	Outlet Type Sink	Time 12:51
Sample Number 169.2-32	Room 218	Outlet Type Sink	Time 12:52
Sample Number 169.2-33	Room 111	Outlet Type Sink	Time 12:53
Sample Number 169.2-34	Art Room 112 Far Left	Outlet Type Sink	Time 12:54
Sample Number 169.2-35	Art Room 112 Far Center	Outlet Type Sink	Time 12:55
Sample Number 169.2-36	Art Room 112 Far Right	Outlet Type Sink	Time 12:56
Sample Number 169.2-37	Art Room 112 Close Left	Outlet Type Sink	Time 12:57
Sample Number 169.2-38	Art Room 112 Close Center	Outlet Type Sink	Time 12:58
Sample Number 169.2-39	Art Room 112 Close Right	Outlet Type Sink	Time 12:59
Sample Number 169.2-40	Faculty Room by 113 Lavatory	Outlet Type Sink	Time 13:00
Sample Number 169.2-41	Music Room 113	Outlet Type Sink	Time 13:01
Sample Number 169.2-42	Auditorium Girl's Lavatory Left	Outlet Type Sink	Time 13:02
Sample Number 169.2-43	Auditorium Girl's Lavatory Right	Outlet Type Sink	Time 13:03
Sample Number 169.2-44	Counseling Center	Outlet Type Sink	Time 13:04
Sample Number 169.2-45	Administrative Office Kitchenette	Outlet Type Sink	Time 13:05
Sample Number 169.2-46	Administrative Office Lavatory	Outlet Type Sink	Time 13:06
Sample Number 169.2-47	Auditorium Boy's Lavatory Left	Outlet Type Sink	Time 13:07
Sample Number 169.2-48	Auditorium Boy's Lavatory Right	Outlet Type Sink	Time 13:08
Sample Number 169.2-49	Copy Room Lavatory	Outlet Type Sink	Time 13:09
Sample Number 169.2-51	Room 108A	Outlet Type Sink	Time 13:10
Sample Number 169.2-52	Room 108	Outlet Type Sink	Time 13:11

Sample Number 169.2-53	Nurse Ice Machine	Outlet Type Ice Machine	Time 13:12
Sample Number 169.2-54	Nurse Back Lavatory	Outlet Type Sink	Time 13:13
Sample Number 169.2-55	Nurse Main Handwash	Outlet Type Sink	Time 13:14
Sample Number 169.2-56	Nurse Front Lavatory	Outlet Type Sink	Time 13:15
Sample Number 169.2-57A	106 Hallway	Outlet Type D F	Time 13:16
Sample Number 169.2-57B	106 Hallway	Outlet Type D F B	Time 13:17
Sample Number 169.2-58	104 106 Middle Office Left	Outlet Type Sink	Time 13:18
Sample Number 169.2-59	104 106 Middle Office Right	Outlet Type Sink	Time 13:19
Sample Number 169.2-60	100 Hallway Men's Lavatory Left	Outlet Type Sink	Time 13:20
Sample Number 169.2-61	100 Hallway Men's Lavatory Center	Outlet Type Sink	Time 13:21
Sample Number 169.2-62	100 Hallway Men's Lavatory Right	Outlet Type Sink	Time 13:22
Sample Number 169.2-63A	100 Hallway	Outlet Type D F	Time 13:23
Sample Number 169.2-63B	100 Hallway	Outlet Type D F B	Time 13:24
Sample Number 169.2-64	100 Hallway Girl's Lavatory Left	Outlet Type Sink	Time 13:25
Sample Number 169.2-65	100 Hallway Girl's Lavatory Center	Outlet Type Sink	Time 13:26
Sample Number 169.2-66	100 Hallway Girl's Lavatory Right	Outlet Type Sink	Time 13:27
Sample Number 169.2-67	Shop Room 164	Outlet Type Sink	Time 13:28
Sample Number 169.2-68	Girls Locker Room Hallway Left	Outlet Type D F	Time 13:29
Sample Number 169.2-69	Girls Locker Room Hallway Right	Outlet Type D F	Time 13:30
Sample Number 169.2-70	Girls Team Room	Outlet Type Sink	Time 13:31
Sample Number 169.2-71	Girls Gym Locker Vestibule Left	Outlet Type D F	Time 13:32
Sample Number 169.2-72	Girls Gym Locker Vestibule Right	Outlet Type D F	Time 13:33
Sample Number 169.2-73	Girls Gym Locker Lavatory Left	Outlet Type Sink	Time 13:34
Sample Number 169.2-74	Girls Gym Lavatory Left Center	Outlet Type Sink	Time 13:35
Sample Number 169.2-75	Girls Gym Locker Lavatory Right Center	Outlet Type Sink	Time 13:36
Sample Number 169.2-76	Girls Gym Locker Lavatory Right	Outlet Type Sink	Time 13:37
Sample Number 169.2-77	Girls Gym Coach Office Lavatory	Outlet Type Sink	Time 13:38
Sample Number 169.2-78	Girls Lavatory by 159 Left	Outlet Type Sink	Time 13:39
Sample Number 169.2-79	Girls Lavatory by 159 Left Center	Outlet Type Sink	Time 13:40
Sample Number 169.2-80	Girls Lavatory by 159 Right Center	Outlet Type Sink	Time 13:41
Sample Number 169.2-81	Girls lavatory by 159 Right	Outlet Type Sink	Time 13:42
Sample Number 169.2-82	Faculty Work Room 159	Outlet Type Sink	Time 13:43
Sample Number 169.2-83	Faculty Work Room 155	Outlet Type Sink	Time 13:44
Sample Number 169.2-84	Boys Lavatory by 155 Left	Outlet Type Sink	Time 13:45
Sample Number 169.2-85	Boys Lavatory by 155 Left Center	Outlet Type Sink	Time 13:46
Sample Number 169.2-86	Boys Lavatory by 155 Right Center	Outlet Type Sink	Time 13:47
Sample Number 169.2-88	Boys Team Room	Outlet Type Sink	Time 13:48
Sample Number 169.2-89	Boys Locker Room Hallway Left	Outlet Type D F	Time 13:49
Sample Number 169.2-90	Boys Locker Room Hallway Right	Outlet Type D F	Time 13:50
Sample Number 169.2-91	Boys Gym Coach Office Lavatory	Outlet Type Sink	Time 13:51
Sample Number 169.2-92	Boys Gym Locker Vestibule	Outlet Type D F	Time 13:52
Sample Number 169.2-93	Boys Gym Locker Lavatory Left	Outlet Type Sink	Time 13:53
Sample Number 169.2-94	Boys Gym Locker Lavatory Left Center	Outlet Type Sink	Time 13:54
Sample Number 169.2-95	Boys Gym Locker Lavatory Right Center	Outlet Type Sink	Time 13:55
Sample Number 169.2-96	Boys Gym Locker Lavatory Right	Outlet Type Sink	Time 13:56
Sample Number 169.2-97A	Cafeteria Hallway	Outlet Type D F	Time 13:57
Sample Number 169.2-97B	Cafeteria Hallway	Outlet Type D F B	Time 13:58
Sample Number 169.2-98	Room 120	Outlet Type Sink	Time 13:59

Sample Number 169.2-100	Kitchen Lavatory	Outlet Type Sink	Time 14:00
Sample Number 169.2-101	Kitchen Kettle Sprayer	Outlet Type Sink	Time 14:01
Sample Number 169.2-102	Kitchen Single Bay by Kettle	Outlet Type Sink	Time 14:02
Sample Number 169.2-103	Kitchen Dish Sprayer South Wall Left	Outlet Type Sink	Time 14:03
Sample Number 169.2-104	Kitchen Dish Sprayer South Wall Right	Outlet Type Sink	Time 14:04
Sample Number 169.2-105	Kitchen Dish Spray by 3 Bay	Outlet Type Sink	Time 14:05
Sample Number 169.2-106	Kitchen Faucet Next to 3 Bay	Outlet Type Sink	Time 14:06
Sample Number 169.2-107	Kitchen 3 Bay Left	Outlet Type Sink	Time 14:07
Sample Number 169.2-108	Kitchen 3 Bay Right	Outlet Type Sink	Time 14:08
Sample Number 169.2-109	Kitchen Handwash by Dish Room	Outlet Type Sink	Time 14:09
Sample Number 169.2-110	Kitchen Sprayer Next to 2 Bay	Outlet Type Sink	Time 14:10
Sample Number 169.2-111	Kitcehn 2 Bay	Outlet Type Sink	Time 14:11
Sample Number 169.2-112	Kitchen Handwash by Serving	Outlet Type Sink	Time 14:12
Sample Number 169.2-113A	Cafeteria Fountain	Outlet Type D F	Time 14:13
Sample Number 169.2-113B	Cafeteria Fountain	Outlet Type D F B	Time 14:14
Sample Number 169.2-114A	116 Hallway	Outlet Type D F	Time 14:15
Sample Number 169.2-114B	116 Hallway	Outlet Type D F B	Time 14:16
Sample Number 169.2-115	116 Hallway Lavatory	Outlet Type Sink	Time 14:17

Please e-mail lab results to [labs@stohlenv.com](mailto:labs@stohlenv.com) If checked, also e-mail results to:

[Ehenderson@StohlEnv.com](mailto:Ehenderson@StohlEnv.com)

Sampled By: Christine. Schultz Stohl Environmental 10/17/2020

Relinquished By: Eric Henderson Jr. 10/19/2020

Received (Name, Laboratory): K T Harris 10/22/20 at 1:42pm

Sample Login (Name, Laboratory): Traci Bloom 11/12/2020 at 9:32am

Analysis (Name, Laboratory): J. Hertzler 11/11/2020 at 7pm

Archived, Released: signature 11/13/2020 at 12pm