

Lancaster Central School District Water Sampling Remediation Plan

Central Avenue Room 119 Sink

Initial Sample EPA Action Limit micrograms per liter	17.5
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	Reflush
New Sample EPA Action Limit micrograms per liter	23.5
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	to Be Determined

Central Avenue Women's lavatory across from 131, sink closest to door

Initial Sample EPA Action Limit micrograms per liter	15.3
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	Reflush
New Sample EPA Action Limit micrograms per liter	10.6
Date Taken Out of Service	service resumed 6/4/2021
Planned Remediation Measure	Not applicable

Central Avenue Women's lavatory across from 131, sink closest to window

Initial Sample EPA Action Limit micrograms per liter	31.3
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	Reflush
New Sample EPA Action Limit micrograms per liter	less than 1
Date Taken Out of Service	service resumed 6/4/2021
Planned Remediation Measure	Not applicable

Central Avenue Men's lavatory across from 131, sink closest to door

Initial Sample EPA Action Limit micrograms per liter	21.8
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	Reflush
New Sample EPA Action Limit micrograms per liter	24.9
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	to Be Determined

Central Avenue Men's lavatory across from 131, sink center left

Initial Sample EPA Action Limit micrograms per liter	17.7
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	Reflush
New Sample EPA Action Limit micrograms per liter	14.8
Date Taken Out of Service	service resumed 6/4/2021
Planned Remediation Measure	Not applicable

Central Avenue Room 135 sink

Initial Sample EPA Action Limit micrograms per liter	33.2
Date Taken Out of Service	12/15/2020
Planned Remediation Measure	Reflush
New Sample EPA Action Limit micrograms per liter	21.9

Date Taken Out of Service 12/15/2020
Planned Remediation Measure to Be Determined

Central Avenue Room 131 sink

Initial Sample EPA Action Limit micrograms per liter 36.4
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 20.7
Date Taken Out of Service 12/15/2020
Planned Remediation Measure to Be Determined

Central Avenue Boy's lavatory in main entry way, sink

Initial Sample EPA Action Limit micrograms per liter 17.2
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 16.4
Date Taken Out of Service 12/15/2020
Planned Remediation Measure to Be Determined

Como Park Room 114 bubbler

Initial Sample EPA Action Limit micrograms per liter 181
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Removed
New Sample EPA Action Limit micrograms per liter Not applicable
Date Taken Out of Service 12/15/2020
Planned Remediation Measure to Be Determined

Como Park Room 207 sink

Initial Sample EPA Action Limit micrograms per liter 15.4
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 15.2
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

Como Park Room 208 sink

Initial Sample EPA Action Limit micrograms per liter 47
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 56
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

Como Park Room 204 sink

Initial Sample EPA Action Limit micrograms per liter 18.2
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 21.7

Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

Como Park Room 211 sink

Initial Sample EPA Action Limit micrograms per liter 18.1
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 25.3
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

Como Park Room 223 sink

Initial Sample EPA Action Limit micrograms per liter 18.9
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 23.1
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

Como Park Girl's lavatory sink 220 far right

Initial Sample EPA Action Limit micrograms per liter 16.6
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 4.94
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

Court Street Cafeteria kitchen hallway bubbler

Initial Sample EPA Action Limit micrograms per liter 19.8
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Removed
New Sample EPA Action Limit micrograms per liter Not applicable
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

Hillview Outdoor access Room 12 girl's lavatory sink

Initial Sample EPA Action Limit micrograms per liter 62.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 59
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Hillview Outdoor access Room 9 boy's lavatory sink

Initial Sample EPA Action Limit micrograms per liter 41.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 27.8

Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

John A. Sciole Room 1 sink

Initial Sample EPA Action Limit micrograms per liter 23
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 35.4
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

John A. Sciole Faculty lavatory left sink

Initial Sample EPA Action Limit micrograms per liter n/a
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 1.8
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

John A. Sciole Room 18 sink

Initial Sample EPA Action Limit micrograms per liter not applicable
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 2.4
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

John A. Sciole Outdoor restroom sink

Initial Sample EPA Action Limit micrograms per liter 17.2
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 24.2
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

John A. Sciole Kitchen pan fill sink sprayer

Initial Sample EPA Action Limit micrograms per liter 25.7
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 84.9
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

William Street School Kitchen serving area hand wash sink

Initial Sample EPA Action Limit micrograms per liter 22.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 2.1

Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

William Street School B106 sprayer
Initial Sample EPA Action Limit micrograms per liter 16.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Removed
New Sample EPA Action Limit micrograms per liter Not applicable
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

William Street School B112 band lesson sink
Initial Sample EPA Action Limit micrograms per liter 28.3
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 3.69
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

William Street School B206 sprayer
Initial Sample EPA Action Limit micrograms per liter 66.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Removed
New Sample EPA Action Limit micrograms per liter Not applicable
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

William Street School B204 front of room
Initial Sample EPA Action Limit micrograms per liter 121
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 1.28
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

William Street School D232 sprayer
Initial Sample EPA Action Limit micrograms per liter 18.6
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Removed
New Sample EPA Action Limit micrograms per liter Not applicable
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 217 vestibule sink
Initial Sample EPA Action Limit micrograms per liter 36.6
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 39.9

Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 218 sink
Initial Sample EPA Action Limit micrograms per liter 62.6
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 49.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 112 far left sink
Initial Sample EPA Action Limit micrograms per liter 40.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 28.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 112 far center sink
Initial Sample EPA Action Limit micrograms per liter 18.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 11.6
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

Lancaster Middle School Room 112 far right sink
Initial Sample EPA Action Limit micrograms per liter 32.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 39.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 112 closest left sink
Initial Sample EPA Action Limit micrograms per liter 61.2
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 35.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 112 closest center sink
Initial Sample EPA Action Limit micrograms per liter 20.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Removed
New Sample EPA Action Limit micrograms per liter Not applicable

Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 112 closest right sink
Initial Sample EPA Action Limit micrograms per liter 15.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 28
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 108 sink
Initial Sample EPA Action Limit micrograms per liter 33.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 43.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster Middle School Room 120 sink
Initial Sample EPA Action Limit micrograms per liter 15.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 29.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Kitchen single bay sink, center
Initial Sample EPA Action Limit micrograms per liter 19.6
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 19.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 168 sink center
Initial Sample EPA Action Limit micrograms per liter 36.1
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 19.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Boys pool locker room bathroom sink
Initial Sample EPA Action Limit micrograms per liter 16.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 19.3

Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Boys pool locker room drinking fountain
Initial Sample EPA Action Limit micrograms per liter 30.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 13.8
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

Lancaster High School Room 167 left sink
Initial Sample EPA Action Limit micrograms per liter 47
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 2.02
Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

Lancaster High School Room 166 left sink
Initial Sample EPA Action Limit micrograms per liter 36.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 25.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 166 right sink
Initial Sample EPA Action Limit micrograms per liter 15.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 19.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 166 far right sink
Initial Sample EPA Action Limit micrograms per liter 26.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 23
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 151 front sink left
Initial Sample EPA Action Limit micrograms per liter 15.3
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 18.7

Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 140 sink
Initial Sample EPA Action Limit micrograms per liter 17.6
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 21.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 138A sink
Initial Sample EPA Action Limit micrograms per liter 18.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 88.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 136A sink
Initial Sample EPA Action Limit micrograms per liter 24.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 19.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 111A office sink
Initial Sample EPA Action Limit micrograms per liter 52.1
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 48
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 114A sink
Initial Sample EPA Action Limit micrograms per liter 15.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 15.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room S11/S12 prep room sink
Initial Sample EPA Action Limit micrograms per liter 48.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 14.6

Date Taken Out of Service service resumed 6/4/2021
Planned Remediation Measure Not applicable

Lancaster High School S13 hallway drinking fountain
Initial Sample EPA Action Limit micrograms per liter 33.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 24.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room S13/S14 prep room sink
Initial Sample EPA Action Limit micrograms per liter 37.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 48.7
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 128A sink
Initial Sample EPA Action Limit micrograms per liter 15.3
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 18.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 129 back sink
Initial Sample EPA Action Limit micrograms per liter 16.1
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 17.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Faculty lavatory 112A right sink
Initial Sample EPA Action Limit micrograms per liter 19.1
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 21.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School 2nd floor north men's faculty lavatory center sink
Initial Sample EPA Action Limit micrograms per liter 35.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 37.1

Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School 2nd floor north men's faculty lavatory right sink
Initial Sample EPA Action Limit micrograms per liter 54.4
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 52.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School 2nd floor north women's faculty lavatory left sink
Initial Sample EPA Action Limit micrograms per liter 35.5
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 33.6
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 217 north sink
Initial Sample EPA Action Limit micrograms per liter 19.9
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 18.8
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

Lancaster High School Room 221 sink
Initial Sample EPA Action Limit micrograms per liter 16.3
Date Taken Out of Service 12/14/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 17.1
Date Taken Out of Service 12/14/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Main men's lavatory sink right
Initial Sample EPA Action Limit micrograms per liter 17.4
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 32.7
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Main women's lavatory sink left
Initial Sample EPA Action Limit micrograms per liter 47
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 48.4

Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Main women's lavatory sink middle
Initial Sample EPA Action Limit micrograms per liter 25.7
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 29.2
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Main women's lavatory sink right
Initial Sample EPA Action Limit micrograms per liter 34.8
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 43.9
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Football locker room sink middle
Initial Sample EPA Action Limit micrograms per liter 49.1
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 897
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Football locker room sink back
Initial Sample EPA Action Limit micrograms per liter 16.5
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 15.6
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Back break room sink front
Initial Sample EPA Action Limit micrograms per liter 26.8
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 45.9
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Back break room sink left lavatory
Initial Sample EPA Action Limit micrograms per liter 31.2
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 16.4

Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

295 Pleasant View Back break room sink right lavatory
Initial Sample EPA Action Limit micrograms per liter 28.5
Date Taken Out of Service 12/15/2020
Planned Remediation Measure Reflush
New Sample EPA Action Limit micrograms per liter 17.3
Date Taken Out of Service 12/15/2020
Planned Remediation Measure To Be Determined

Lancaster High School Lab 138 North Wall Left
Initial Sample EPA Action Limit micrograms per liter 47.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 138 North Wall Right
Initial Sample EPA Action Limit micrograms per liter 67.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 138 East Wall Left
Initial Sample EPA Action Limit micrograms per liter 22.7
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 138 Teacher Desk
Initial Sample EPA Action Limit micrograms per liter 62.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 136 Teacher Desk
Initial Sample EPA Action Limit micrograms per liter 43.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 136 East Wall Right
Initial Sample EPA Action Limit micrograms per liter 16.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 136 South Wall Left
Initial Sample EPA Action Limit micrograms per liter 38.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 136 South Wall Right
Initial Sample EPA Action Limit micrograms per liter 41.4

Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 West Wall South Sink Left
Initial Sample EPA Action Limit micrograms per liter 16.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 West Wall North Sink Left
Initial Sample EPA Action Limit micrograms per liter 28.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 West Wall North Sink Right
Initial Sample EPA Action Limit micrograms per liter 16.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 Teacher Desk North
Initial Sample EPA Action Limit micrograms per liter 15.8
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 Teacher Desk South
Initial Sample EPA Action Limit micrograms per liter 21.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 South Wall East Sink Left
Initial Sample EPA Action Limit micrograms per liter 46.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 South Wall Center Sink Left
Initial Sample EPA Action Limit micrograms per liter 22.4
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 134 South Wall West Sink Right
Initial Sample EPA Action Limit micrograms per liter 198
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 130 North Wall West Sink Right
Initial Sample EPA Action Limit micrograms per liter 44.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 130 North Wall East Sink Right
Initial Sample EPA Action Limit micrograms per liter 47.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 130 East Wall Center Sink Left
Initial Sample EPA Action Limit micrograms per liter 28.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 130 East Wall Center Sink Right
Initial Sample EPA Action Limit micrograms per liter 25.4
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Prep Room 130A Left
Initial Sample EPA Action Limit micrograms per liter 16.8
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab Room 128 Teacher Desk Left
Initial Sample EPA Action Limit micrograms per liter 26.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Prep Room 128A Left
Initial Sample EPA Action Limit micrograms per liter 38.7
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Room 131A Left
Initial Sample EPA Action Limit micrograms per liter 18.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Room 131 Teacher Desk Left
Initial Sample EPA Action Limit micrograms per liter 63.4
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 East Wall North Sink Left
Initial Sample EPA Action Limit micrograms per liter 33.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School La S16 East Wall North Sink Right
Initial Sample EPA Action Limit micrograms per liter 53.1
Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 East Wall 2nd North Sink Left

Initial Sample EPA Action Limit micrograms per liter 97.3

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 East Wall 2nd North Sink Right

Initial Sample EPA Action Limit micrograms per liter 34.7

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 East Wall 2nd South Sink Left

Initial Sample EPA Action Limit micrograms per liter 37.6

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 East Wall 2nd South Sink Right

Initial Sample EPA Action Limit micrograms per liter 24.2

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 East Wall South Sink Left

Initial Sample EPA Action Limit micrograms per liter 26.3

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 East Wall South Sink Right

Initial Sample EPA Action Limit micrograms per liter 27.9

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 South Wall East Sink Left

Initial Sample EPA Action Limit micrograms per liter 18.9

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 South Wall Center Sink Left

Initial Sample EPA Action Limit micrograms per liter 19.2

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 South Wall Center Sink Right

Initial Sample EPA Action Limit micrograms per liter 25.9

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 South Wall Right Sink

Initial Sample EPA Action Limit micrograms per liter 57.3
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S16 Teachers Desk
Initial Sample EPA Action Limit micrograms per liter 73.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S15 Teachers Desk
Initial Sample EPA Action Limit micrograms per liter 29.3
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S15 South Wall East Sink
Initial Sample EPA Action Limit micrograms per liter 100
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S15 South Wall Center Sink Right
Initial Sample EPA Action Limit micrograms per liter 16.8
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S15 West Wall 2nd South Sink Left
Initial Sample EPA Action Limit micrograms per liter 15.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S15 North Wall
Initial Sample EPA Action Limit micrograms per liter 32.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S14 North Wall
Initial Sample EPA Action Limit micrograms per liter 31.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S14 South Wall West Sink
Initial Sample EPA Action Limit micrograms per liter 34.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S14 Teacher Desk
Initial Sample EPA Action Limit micrograms per liter 31.4
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S13 Teacher Desk
Initial Sample EPA Action Limit micrograms per liter 22
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S13 South Wall East Sink
Initial Sample EPA Action Limit micrograms per liter 71.7
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S13 North Wall
Initial Sample EPA Action Limit micrograms per liter 16.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S12 North Wall
Initial Sample EPA Action Limit micrograms per liter 18.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S12 South Wall West Sink
Initial Sample EPA Action Limit micrograms per liter 57.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S12 Teacher Desk
Initial Sample EPA Action Limit micrograms per liter 55.5
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S11 Teacher Desk
Initial Sample EPA Action Limit micrograms per liter 58.7
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S11 South Wall East Sink
Initial Sample EPA Action Limit micrograms per liter 32.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab S11 North Wall
Initial Sample EPA Action Limit micrograms per liter 22.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 111 Teacher Desk Left
Initial Sample EPA Action Limit micrograms per liter 252

Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 111 Teacher Desk Right
Initial Sample EPA Action Limit micrograms per liter 179
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 111 West Wall Center Sink Left
Initial Sample EPA Action Limit micrograms per liter 26.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 111 West Wall North Sink Left
Initial Sample EPA Action Limit micrograms per liter 28.7
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 Teachers Desk
Initial Sample EPA Action Limit micrograms per liter 46.3
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 West Wall
Initial Sample EPA Action Limit micrograms per liter 38.6
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 West Row Center Sink Left
Initial Sample EPA Action Limit micrograms per liter 23.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 West Row Center Sink Right
Initial Sample EPA Action Limit micrograms per liter 44.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 West Row North Sink Left
Initial Sample EPA Action Limit micrograms per liter 21.8
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 West Row North Sink Right
Initial Sample EPA Action Limit micrograms per liter 28.8
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 East Row North Sink Left
Initial Sample EPA Action Limit Micrograms per liter 27.5
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 East Row North Sink Right
Initial Sample EPA Action Limit Micrograms per liter 18.4
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 109 East Row Center Sink Right
Initial Sample EPA Action Limit Micrograms per liter 18.5
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster High School Lab 107 West Wall South Sink
Initial Sample EPA Action Limit micrograms per liter 16.3
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Island Sink
Initial Sample EPA Action Limit micrograms per liter 78.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Back Wall Left Sink
Initial Sample EPA Action Limit micrograms per liter 31.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Back Wall Second to Left Sink
Initial Sample EPA Action Limit micrograms per liter 54.8
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Back Wall Third to Left Sink
Initial Sample EPA Action Limit micrograms per liter 63.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Back Wall Third to Right Sink
Initial Sample EPA Action Limit micrograms per liter 61.7
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Back Wall Second to Right Sink
Initial Sample EPA Action Limit micrograms per liter 43.7
Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Back Wall Right Sink

Initial Sample EPA Action Limit micrograms per liter 48.8

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Right Wall Left Sink

Initial Sample EPA Action Limit micrograms per liter 24.7

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Right Wall Left Middle Sink

Initial Sample EPA Action Limit micrograms per liter 49

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Right Wall Right Middle Sink

Initial Sample EPA Action Limit micrograms per liter 17.5

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 309 Right Wall Right Sink

Initial Sample EPA Action Limit micrograms per liter 37.2

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Island Sink

Initial Sample EPA Action Limit micrograms per liter 61.3

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Teachers Sink

Initial Sample EPA Action Limit micrograms per liter 16

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Left Wall Left Sink

Initial Sample EPA Action Limit micrograms per liter 49.9

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Left Wall Left Middle Sink

Initial Sample EPA Action Limit micrograms per liter 62.6

Date Taken Out of Service Not applicable

Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Left Wall Right Middle Sink

Initial Sample EPA Action Limit micrograms per liter 34.9
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Left Wall Right Sink
Initial Sample EPA Action Limit micrograms per liter 27.1
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Back Wall Left Sink
Initial Sample EPA Action Limit micrograms per liter 49.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Back Wall Second to Left Sink
Initial Sample EPA Action Limit micrograms per liter 88.5
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Back Wall Third to Left Sink
Initial Sample EPA Action Limit micrograms per liter 34.2
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Back Wall Third to Right Sink
Initial Sample EPA Action Limit micrograms per liter 61.5
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Back Wall Second to Right Sink
Initial Sample EPA Action Limit micrograms per liter 38.8
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption

Lancaster Middle School Lab 301 Back Wall Right Sink
Initial Sample EPA Action Limit micrograms per liter 33.4
Date Taken Out of Service Not applicable
Planned Remediation Measure Label Handwash Only/Not for Consumption